

Corvallis School District

Radon Testing Results

- The EPA's recommended action level for radon is **4 pCi/L** and will require mitigation by the district, followed by retesting.
- [X number] of spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.

Site Name	Room Description (per floor plan)	Kit Serial #	Date Sampled	Results (pCi/L)
Corvallis High School	OFFICE	4882136	2/1/2020	0.6
Corvallis High School	OFFICE	4882104	2/1/2020	0.7
Corvallis High School	OFFICE	4882085	2/1/2020	0.7
Corvallis High School	OFFICE	4902489	2/1/2020	1
Corvallis High School	120	4902368	2/1/2020	0.5
Corvallis High School	119	4882133	2/1/2020	0.6
Corvallis High School	118	4902185	2/1/2020	0.7
Corvallis High School	117	4881990	2/1/2020	1.2
Corvallis High School	116	4902289	2/1/2020	1.1
Corvallis High School	116 (DUP)	4885905	2/1/2020	1.2
Corvallis High School	115	4902118	2/1/2020	0.7
Corvallis High School	114	4902132	2/1/2020	0.8
Corvallis High School	113	4902590	2/1/2020	0.5
Corvallis High School	112	4878384	2/1/2020	0.5
Corvallis High School	111	4902123	2/1/2020	0.2
Corvallis High School	110	4882141	2/1/2020	1.7
Corvallis High School	109	4878382	2/1/2020	1.6
Corvallis High School	108	4902225	2/1/2020	1.7
Corvallis High School	108 (DUP)	4882409	2/1/2020	1.1
Corvallis High School	107	4882063	2/1/2020	0.9
Corvallis High School	106	4902120	2/1/2020	1.1
Corvallis High School	105	4902547	2/1/2020	1.0
Corvallis High School	104	4902256	2/1/2020	0.8
Corvallis High School	103	4882152	2/1/2020	0.6
Corvallis High School	102	4902221	2/1/2020	0.7
Corvallis High School	101	4882296	2/1/2020	0.7
Corvallis High School	101 (DUP)	4902251	2/1/2020	0.8
Corvallis High School	LIB	4902200	2/1/2020	0.9
Corvallis High School	LIB	4902325	2/1/2020	0.8
Corvallis High School	GYM	4886191	2/1/2020	0.6
Corvallis High School	GYM	4902331	2/1/2020	0.8
Corvallis High School	GYM	4902402	2/1/2020	0.7
Corvallis High School	GYM	4882463	2/1/2020	1.3
Corvallis High School	GYM (DUP)	4902283	2/1/2020	1.1
Corvallis High School	GYM (DUP)	4902303	2/1/2020	0.7
Corvallis High School	GYM (BLANK)	4902166	2/1/2020	0.2
Corvallis High School	WEIGHT ROOM	4882054	2/1/2020	0.4
Corvallis High School	COMMONS	4878398	2/1/2020	0.2

Corvallis School District**Radon Testing Results**

- The EPA's recommended action level for radon is **4 pCi/L** and will require mitigation by the district, followed by retesting.
- [X number] of spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.

Site Name	Room Description (per floor plan)	Kit Serial #	Date Sampled	Results (pCi/L)
Corvallis High School	COMMONS	4882119	2/1/2020	0.4
Corvallis High School	COMMONS	4902346	2/1/2020	0.5
Corvallis High School	COMMONS	4902262	2/1/2020	0.5
Corvallis High School	P10	4882187	2/1/2020	0.6
Corvallis High School	P4	4902475	2/1/2020	0.4
Corvallis High School	P3	4902156	2/1/2020	0.4
Corvallis High School	AUD	4902113	2/1/2020	0.9
Corvallis High School	AUD	4902318	2/1/2020	0.5
Corvallis High School	AUD	4882166	2/1/2020	0.5
Corvallis High School	P2	4902124	2/1/2020	0.8
Corvallis High School	P1	4902184	2/1/2020	0.9
Corvallis High School	P1(DUP)	4902310	2/1/2020	0.8
Corvallis High School	OFFICE	4882118	2/1/2020	0.7
Corvallis High School	OFFICE	4902415	2/1/2020	0.8
Corvallis High School	OFFICE	4902978	2/1/2020	0.8
Corvallis High School	OFFICE	4882483	2/1/2020	0.8
Corvallis High School	OFFICE	4902236	2/1/2020	0.3
Corvallis High School	OFFICE	4902217	2/1/2020	0.7
Corvallis High School	SHOP	4882526	2/1/2020	0.2
Corvallis High School	SHOP	4902514	2/1/2020	0.4
Corvallis High School	SHOP	4902414	2/1/2020	0.6
Corvallis High School	SHOP (DUP)	4902278	2/1/2020	0.4
Corvallis High School	T39	4882243	2/1/2020	0.7
Corvallis High School	T38B	4882418	2/1/2020	0.5
Corvallis High School	T40B	4878381	2/1/2020	0.4
Corvallis High School	T40	4882389	2/1/2020	0.5
Corvallis High School	T40	4885998	2/1/2020	0.4
Corvallis High School	T40	4902347	2/1/2020	0.4
Corvallis High School	T40 (DUP)	4882084	2/1/2020	0.5
Corvallis High School	T42	4902151	2/1/2020	0.5
Corvallis High School	T42	4902106	2/1/2020	0.8
Corvallis High School	T42 (BLANK)	4878393	2/1/2020	0.2
Corvallis High School	T16	4902432	2/1/2020	0.2
Corvallis High School	T15	4902324	2/1/2020	0.2
Corvallis High School	T14	4902561	2/1/2020	1.4
Corvallis High School	T14 (DUP)	4882192	2/1/2020	1.3
Corvallis High School	T14A	4902232	2/1/2020	0.4
Corvallis High School	T13	4902154	2/1/2020	0.9

Corvallis School District

Radon Testing Results

- The EPA's recommended action level for radon is **4 pCi/L** and will require mitigation by the district, followed by retesting.
- [X number] of spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.

Site Name	Room Description (per floor plan)	Kit Serial #	Date Sampled	Results (pCi/L)
Corvallis High School	T12	4902114	2/1/2020	0.2
Corvallis High School	T11	4902317	2/1/2020	0.3
Corvallis High School	T11 (BLANK)	4885992	2/1/2020	0.2
Corvallis High School	H3	4881963	2/1/2020	0.7
Corvallis High School	H3	4902567	2/1/2020	0.8
Corvallis High School	H3	4882145	2/1/2020	0.9
Corvallis High School	H3 (DUP)	4902131	2/1/2020	1.2
Corvallis High School	H4	4902521	2/1/2020	0.9
Corvallis High School	H7	902359	2/1/2020	1.1
Corvallis High School	H6	4878388	2/1/2020	1.6
Corvallis High School	H2	4902204	2/1/2020	1.2
Corvallis High School	H2	4882225	2/1/2020	1.5
Corvallis High School	H2 (DUP)	4878372	2/1/2020	1.1
Corvallis High School	H1	4902126	2/1/2020	1.3
Corvallis High School	H5	4878383	2/1/2020	1.2
Corvallis High School	H5	4902099	2/1/2020	1.2
Corvallis High School	H5	4882008	2/1/2020	1.2
Corvallis High School	H5 (BLANK)	4902146	2/1/2020	0.7