

Corvallis School District

Radon Testing Results

- The EPA's recommended action level for radon is **4 pCi/L** and will require mitigation by the district, followed by retesting.
- [X number] of spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.

Site Name	Room Description (per floor plan)	Kit Serial #	Date Sampled	Results (pCi/L)
District Office - Administration	1-BOARD	4882317	1/31/2020	0.2
District Office - Administration	1-DUP	4885927	1/31/2020	0.4
District Office - Administration	4	4902140	1/31/2020	0.7
District Office - Administration	6	4902417	1/31/2020	0.5
District Office - Administration	8	4902155	1/31/2020	0.5
District Office - Administration	24	4882132	1/31/2020	0.6
District Office - Administration	9A	4902322	1/31/2020	0.6
District Office - Administration	9	4902235	1/31/2020	0.7
District Office - Administration	11A	4902228	1/31/2020	0.7
District Office - Administration	10	4902152	1/31/2020	0.7
District Office - Administration	11	4902330	1/31/2020	0.5
District Office - Administration	23	4881992	1/31/2020	0.6
District Office - Administration	12	4902237	1/31/2020	0.8
District Office - Administration	13	4902133	1/31/2020	0.5
District Office - Administration	15	4882059	1/31/2020	0.6
District Office - Administration	26	4902255	1/31/2020	2.0
District Office - Administration	18	4885962	1/31/2020	0.7
District Office - Administration	19	4902566	1/31/2020	0.7
District Office - Administration	20	4902506	1/31/2020	0.8
District Office - Administration	20 DUP	4882292	1/31/2020	0.9
District Office - Administration	20 BLANK	4902343	1/31/2020	0.2
District Office - Administration	50	4882156	1/31/2020	0.4
District Office - Administration	52	4882294	1/31/2020	0.3
District Office - Administration	PLANS	4902496	1/31/2020	0.2
District Office - Administration	49	4882217	1/31/2020	0.6
District Office - Administration	58	4882478	1/31/2020	0.2
District Office - Administration	58 BLANK	4902129	1/31/2020	0.2
District Office - Administration	30A	4882101	1/31/2020	0.2
District Office - Administration	51	4902384	1/31/2020	0.4
District Office - Administration	49	4885968	1/31/2020	0.4
District Office - Administration	37	4902341	1/31/2020	0.2
District Office - Administration	38	4902253	1/31/2020	0.3
District Office - Administration	38A	4902105	1/31/2020	0.3
District Office - Administration	39	4902487	1/31/2020	0.3
District Office - Administration	42	4902576	1/31/2020	0.4
District Office - Administration	41	4882421	1/31/2020	1.0
District Office - Administration	35	4878385	1/31/2020	0.3
District Office - Administration	35 (DUP)	4902463	1/31/2020	0.3

Corvallis School District

Radon Testing Results

- The EPA's recommended action level for radon is **4 pCi/L** and will require mitigation by the district, followed by retesting.
- [X number] of spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.

Site Name	Room Description (per floor plan)	Kit Serial #	Date Sampled	Results (pCi/L)
District Office - Administration	31A	4882198	1/31/2020	0.6
District Office - Administration	31	4902537	1/31/2020	0.5
District Office - Administration	32	4882364	1/31/2020	0.6
District Office - Administration	36E	4902188	1/31/2020	0.5
District Office - Administration	36D	4882324	1/31/2020	0.2
District Office - Administration	46	4882169	1/31/2020	0.2
District Office - Administration	47	4882308	1/31/2020	0.2
District Office - Administration	48	4902351	1/31/2020	0.3
District Office - Administration	48 (DUP)	4885824	1/31/2020	0.2
District Office - Administration	48 (BLANK)	4902387	1/31/2020	0.2
District Office - Administration	45	4882401	1/31/2020	0.3
District Office - Administration	36C	4885911	1/31/2020	0.2
District Office - Administration	36	4902141	1/31/2020	0.2
District Office - Administration	36B	4902425	1/31/2020	0.9
District Office - Administration	36A	4902226	1/31/2020	0.7