

## Corvallis School District

### Radon Testing Results

- *The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.*
- [X number] of spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.

Site Name	Room Description (per floor plan)	Kit Serial #	Date Sampled	Results (pCi/L)
Garfield Elementary School	1	4882455	2/2/2020	0.5
Garfield Elementary School	2	4882355	2/2/2020	0.8
Garfield Elementary School	3	4902176	2/2/2020	0.5
Garfield Elementary School	4	4882263	2/2/2020	1.3
Garfield Elementary School	5	4882300	2/2/2020	0.9
Garfield Elementary School	6	4882369	2/2/2020	0.9
Garfield Elementary School	CAFÉ	4902538	2/2/2020	0.8
Garfield Elementary School	CAFÉ	4902467	2/2/2020	0.7
Garfield Elementary School	CAFÉ (DUP)	4882503	2/2/2020	0.7
Garfield Elementary School	7	4882472	2/2/2020	0.5
Garfield Elementary School	8	4902407	2/2/2020	0.4
Garfield Elementary School	24	4882445	2/2/2020	0.6
Garfield Elementary School	27	402502	2/2/2020	0.5
Garfield Elementary School	9	4882288	2/2/2020	0.9
Garfield Elementary School	25	4882323	2/2/2020	0.7
Garfield Elementary School	26	4902127	2/2/2020	0.6
Garfield Elementary School	10	4882185	2/2/2020	0.3
Garfield Elementary School	11	4902108	2/2/2020	0.2
Garfield Elementary School	12	4882347	2/2/2020	0.2
Garfield Elementary School	31	4886027	2/2/2020	2.1
Garfield Elementary School	33	4882097	2/2/2020	0.2
Garfield Elementary School	35	4885920	2/2/2020	0.2
Garfield Elementary School	34	4902098	2/2/2020	0.2
Garfield Elementary School	GYM	4902234	2/2/2020	0.6
Garfield Elementary School	GYM	4882092	2/2/2020	0.5
Garfield Elementary School	GYM	4882298	2/2/2020	0.6
Garfield Elementary School	GYM (DUP)	4902587	2/2/2020	1.1
Garfield Elementary School	GYM (BLANK)	4886192	2/2/2020	0.4
Garfield Elementary School	19	4902241	2/2/2020	0.4
Garfield Elementary School	18	4882297	2/2/2020	0.4
Garfield Elementary School	17	4882475	2/2/2020	0.5
Garfield Elementary School	16	4885850	2/2/2020	0.4
Garfield Elementary School	14	4882470	2/2/2020	0.2
Garfield Elementary School	13	4882252	2/2/2020	0.3
Garfield Elementary School	28	4885849	2/2/2020	0.4
Garfield Elementary School	28 (DUP)	4882285	2/2/2020	0.3
Garfield Elementary School	24 (DUP)	4902446	2/2/2020	0.5
Garfield Elementary School	15	4882486	2/2/2020	0.2