

## Corvallis School District

### Radon Testing Results

- *The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.*
- [X number] of spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.

Site Name	Room Description (per floor plan)	Kit Serial #	Date Sampled	Results (pCi/L)
Hoover Elementary School	1	4882515	2/1/2020	0.2
Hoover Elementary School	2	4902337	2/1/2020	0.4
Hoover Elementary School	3	4902289	2/1/2020	0.4
Hoover Elementary School	4	4885930	2/1/2020	0.2
Hoover Elementary School	5	4882322	2/1/2020	0.5
Hoover Elementary School	6	4885971	2/1/2020	0.4
Hoover Elementary School	OFFICE	4882410	2/1/2020	0.2
Hoover Elementary School	OFFICE	4882123	2/1/2020	0.2
Hoover Elementary School	OFFICE	4882261	2/1/2020	0.6
Hoover Elementary School	15	4885884	2/1/2020	0.5
Hoover Elementary School	15 (DUP)	4882407	2/1/2020	0.5
Hoover Elementary School	16	4885898	2/1/2020	0.7
Hoover Elementary School	GYM	4882093	2/1/2020	0.2
Hoover Elementary School	GYM	4882313	2/1/2020	0.4
Hoover Elementary School	GYM	4882356	2/1/2020	0.3
Hoover Elementary School	GYM (DUP)	4902390	2/1/2020	0.2
Hoover Elementary School	GYM (BLANK)	4882371	2/1/2020	0.4
Hoover Elementary School	LIBRARY	4882361	2/1/2020	0.6
Hoover Elementary School	LIBRARY	4882383	2/1/2020	0.5
Hoover Elementary School	LIB (DUP)	4882420	2/1/2020	0.4
Hoover Elementary School	STAFF	4882257	2/1/2020	0.5
Hoover Elementary School	LDF1	4902168	2/1/2020	0.2
Hoover Elementary School	7	4882287	2/1/2020	0.4
Hoover Elementary School	8	4902290	2/1/2020	0.4
Hoover Elementary School	9	4882221	2/1/2020	0.2
Hoover Elementary School	10	4882332	2/1/2020	0.3
Hoover Elementary School	11	4882318	2/1/2020	0.3
Hoover Elementary School	12	4882125	2/1/2020	0.2
Hoover Elementary School	13	4902435	2/1/2020	0.2
Hoover Elementary School	4	4882375	2/1/2020	0.2
Hoover Elementary School	17	4882517	2/1/2020	0.2
Hoover Elementary School	18	4882302	2/1/2020	0.2
Hoover Elementary School	19	4902246	2/1/2020	0.4
Hoover Elementary School	19 (DUP)	4902202	2/1/2020	0.2
Hoover Elementary School	13 BK	4902216	2/1/2020	0.2
Hoover Elementary School	18 (DUP)	4902466	2/1/2020	0.2