

Corvallis School District**Radon Testing Results**

- The EPA's recommended action level for radon is **4 pCi/L** and will require mitigation by the district, followed by retesting.
- [X number] of spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.

Site Name	Room Description (per floor plan)	Kit Serial #	Date Sampled	Results (pCi/L)
Linus Pauling Middle School	OFFICE	4882076	2/2/2020	0.8
Linus Pauling Middle School	OFFICE	4902159	2/2/2020	1.0
Linus Pauling Middle School	OFFICE	4882272	2/2/2020	1.3
Linus Pauling Middle School	OFFICE	4886136	2/2/2020	0.8
Linus Pauling Middle School	101	4886245	2/2/2020	0.8
Linus Pauling Middle School	103A	4902247	2/2/2020	1.0
Linus Pauling Middle School	103B	4882499	2/2/2020	1.1
Linus Pauling Middle School	104	4902222	2/2/2020	0.7
Linus Pauling Middle School	102	4882103	2/2/2020	0.4
Linus Pauling Middle School	LIBRARY	4902321	2/2/2020	0.7
Linus Pauling Middle School	LIBRARY	4882095	2/2/2020	0.6
Linus Pauling Middle School	LIBRARY	4885922	2/2/2020	0.6
Linus Pauling Middle School	LIBRARY (DUP)	4878379	2/2/2020	0.5
Linus Pauling Middle School	107	4885837	2/2/2020	0.5
Linus Pauling Middle School	109	4882326	2/2/2020	0.4
Linus Pauling Middle School	111	4882377	2/2/2020	0.2
Linus Pauling Middle School	112	4886002	2/2/2020	0.4
Linus Pauling Middle School	110	4902231	2/2/2020	0.2
Linus Pauling Middle School	108	4882331	2/2/2020	0.3
Linus Pauling Middle School	106	4882428	2/2/2020	0.5
Linus Pauling Middle School	119	4882429	2/2/2020	0.2
Linus Pauling Middle School	COMMONS	4882397	2/2/2020	0.5
Linus Pauling Middle School	COMMONS	4882309	2/2/2020	0.5
Linus Pauling Middle School	COMMONS	4882424	2/2/2020	0.3
Linus Pauling Middle School	COMMONS (DUP)	4882173	2/2/2020	0.2
Linus Pauling Middle School	COMMONS (BLANK)	4902427	2/2/2020	0.2
Linus Pauling Middle School	MAIN GYM	4885944	2/2/2020	0.5
Linus Pauling Middle School	COST OFF	4882395	2/2/2020	0.2
Linus Pauling Middle School	STUDENT CENTER	4885912	2/2/2020	0.2
Linus Pauling Middle School	MAIN GYM	4882448	2/2/2020	0.8
Linus Pauling Middle School	MAIN GYM	4882260	2/2/2020	0.6
Linus Pauling Middle School	MAIN GYM	4882354	2/2/2020	0.8
Linus Pauling Middle School	MAIN GYM	4882384	2/2/2020	0.5
Linus Pauling Middle School	MAIN (DUP)	4885868	2/2/2020	0.7
Linus Pauling Middle School	MAIN (DUP)	4885812	2/2/2020	1.0
Linus Pauling Middle School	MAIN (BLANK)	4902178	2/2/2020	0.2
Linus Pauling Middle School	MAT ROOM	4882498	2/2/2020	0.6
Linus Pauling Middle School	MAT ROOM	4882338	2/2/2020	0.5

Corvallis School District

Radon Testing Results

- The EPA's recommended action level for radon is **4 pCi/L** and will require mitigation by the district, followed by retesting.
- [X number] of spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.

Site Name	Room Description (per floor plan)	Kit Serial #	Date Sampled	Results (pCi/L)
Linus Pauling Middle School	AUX GYM	4882293	2/2/2020	0.5
Linus Pauling Middle School	AUX GYM	4882415	2/2/2020	0.5
Linus Pauling Middle School	AUX GYM	4886054	2/2/2020	0.4
Linus Pauling Middle School	AUX GYM	4882304	2/2/2020	0.8
Linus Pauling Middle School	AUX (DUP)	4882330	2/2/2020	0.9
Linus Pauling Middle School	114	4902266	2/2/2020	0.5
Linus Pauling Middle School	114	4882314	2/2/2020	0.8
Linus Pauling Middle School	116	4902363	2/2/2020	1.4
Linus Pauling Middle School	116	4885994	2/2/2020	1.6
Linus Pauling Middle School	118	4882282	2/2/2020	1.4
Linus Pauling Middle School	118	4902348	2/2/2020	1.3
Linus Pauling Middle School	118 (DUP)	4882212	2/2/2020	1.2
Linus Pauling Middle School	117	4882233	2/2/2020	1.1
Linus Pauling Middle School	117	4885902	2/2/2020	1.1
Linus Pauling Middle School	115	4882320	2/2/2020	1.7
Linus Pauling Middle School	115	4882352	2/2/2020	1.2
Linus Pauling Middle School	BAND	4887147	2/2/2020	0.8
Linus Pauling Middle School	BAND	488174	2/2/2020	0.9
Linus Pauling Middle School	132	4902261	2/2/2020	0.7
Linus Pauling Middle School	105	4882116	2/2/2020	0.2
Linus Pauling Middle School	AUD	4885906	2/2/2020	0.2