

## Corvallis School District

### Radon Testing Results

- The EPA's recommended action level for radon is **4 pCi/L** and will require mitigation by the district, followed by retesting.
- [X number] of spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.

Site Name	Room Description (per floor plan)	Kit Serial #	Date Sampled	Results (pCi/L)
Mt. View Elementary School	19	4882363	2/2/2020	3.9
Mt. View Elementary School	20	4882274	2/2/2020	3.4
Mt. View Elementary School	22	4882394	2/2/2020	3.5
Mt. View Elementary School	23	4902465	2/2/2020	1.5
Mt. View Elementary School	14	4882120	2/2/2020	0.5
Mt. View Elementary School	16	4882190	2/2/2020	0.3
Mt. View Elementary School	18	4882043	2/2/2020	1.1
Mt. View Elementary School	17	4882527	2/2/2020	0.6
Mt. View Elementary School	15	4902516	2/2/2020	0.6
Mt. View Elementary School	13	4886092	2/2/2020	1.1
Mt. View Elementary School	24	4882350	2/2/2020	1.2
Mt. View Elementary School	33	4885993	2/2/2020	2.2
Mt. View Elementary School	33	4882416	2/2/2020	2.1
Mt. View Elementary School	33 (DUP)	4902326	2/2/2020	2.1
Mt. View Elementary School	12	4902211	2/2/2020	1.0
Mt. View Elementary School	11	4902268	2/2/2020	1.7
Mt. View Elementary School	10	4886159	2/2/2020	1.1
Mt. View Elementary School	9	4885822	2/2/2020	1.5
Mt. View Elementary School	35	4882438	2/2/2020	0.8
Mt. View Elementary School	GYM	4882121	2/2/2020	1.6
Mt. View Elementary School	GYM	4902285	2/2/2020	1.4
Mt. View Elementary School	GYM	4902248	2/2/2020	1.3
Mt. View Elementary School	GYM (DUP)	4882129	2/2/2020	1.4
Mt. View Elementary School	GYM (BLANK)	4878396	2/2/2020	0.2
Mt. View Elementary School	45	4882460	2/2/2020	0.3
Mt. View Elementary School	7	4882170	2/2/2020	0.8
Mt. View Elementary School	5	4882335	2/2/2020	0.9
Mt. View Elementary School	3	4882406	2/2/2020	0.8
Mt. View Elementary School	1	4882105	2/2/2020	1.0
Mt. View Elementary School	2A	4885839	2/2/2020	0.4
Mt. View Elementary School	2	4882496	2/2/2020	0.4
Mt. View Elementary School	4A	4886000	2/2/2020	0.4
Mt. View Elementary School	4B	4902128	2/2/2020	0.5
Mt. View Elementary School	4	4882479	2/2/2020	1.2
Mt. View Elementary School	6	4882139	2/2/2020	1
Mt. View Elementary School	8	4882127	2/2/2020	0.8
Mt. View Elementary School	8 (DUP)	4878391	2/2/2020	0.9
Mt. View Elementary School	1A	4882314	2/2/2020	0.4

## Corvallis School District

### Radon Testing Results

- *The EPA's recommended action level for radon is **4 pCi/L** and will require mitigation by the district, followed by retesting.*
- [X number] of spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.

Site Name	Room Description (per floor plan)	Kit Serial #	Date Sampled	Results (pCi/L)
Mt. View Elementary School	24 (DUP)	4882372	2/2/2020	1.5