

Corvallis School District**Radon Testing Results**

- *The EPA's recommended action level for radon is **4 pCi/L** and will require mitigation by the district, followed by retesting.*
- [X number] of spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.

Site Name	Room Description (per floor plan)	Kit Serial #	Date Sampled	Results (pCi/L)
Wilson Elementary School	10	4902367	2/1/2020	0.2
Wilson Elementary School	9	4882238	2/1/2020	0.4
Wilson Elementary School	7	4882183	2/1/2020	0.3
Wilson Elementary School	5	4902254	2/1/2020	0.2
Wilson Elementary School	3	4886149	2/1/2020	0.2
Wilson Elementary School	1	4882522	2/1/2020	0.2
Wilson Elementary School	2	4902444	2/1/2020	0.4
Wilson Elementary School	4	4882112	2/1/2020	0.3
Wilson Elementary School	6	4882111	2/1/2020	0.2
Wilson Elementary School	8	4902339	2/1/2020	0.2
Wilson Elementary School	GYM	4882004	2/1/2020	0.2
Wilson Elementary School	GYM	4882267	2/1/2020	0.2
Wilson Elementary School	GYM	4902158	2/1/2020	0.2
Wilson Elementary School	GYM (DUP)	4882340	2/1/2020	0.3
Wilson Elementary School	GYM (BLANK)	4882440	2/1/2020	0.2
Wilson Elementary School	11	4882427	2/1/2020	0.2
Wilson Elementary School	13	4902332	2/1/2020	0.2
Wilson Elementary School	15	4882222	2/1/2020	0.2
Wilson Elementary School	17	4882295	2/1/2020	0.2
Wilson Elementary School	19	4885856	2/1/2020	0.2
Wilson Elementary School	21A	4882149	2/1/2020	0.2
Wilson Elementary School	20	4882413	2/1/2020	0.2
Wilson Elementary School	18	4882346	2/1/2020	0.2
Wilson Elementary School	18 (DUP)	4902163	2/1/2020	0.2
Wilson Elementary School	12	4882373	2/1/2020	0.2
Wilson Elementary School	21	4902364	2/1/2020	0.2
Wilson Elementary School	21C	4882316	2/1/2020	0.2