



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

August 15, 2016

Paul Jennison
Corvallis School District
P O Box 3509J
Corvallis, OR 97339
TEL: (541) 757-5853
FAX

RE: Linus Pauling MS

Order No.: 1607708

Dear Paul Jennison:

Analytical Laboratory Group received 48 sample(s) on 7/15/2016 for the analyses presented in the following report.

The analysis was performed according to our laboratory's NELAP/TNI-approved quality assurance program. Any exceptions to this quality assurance program are noted on the case narrative.

Testing methods used are sufficiently sensitive enough to meet the requirements that support client/permittee NPDES permits that we have on file. The client is responsible for reviewing reports. The permittee is responsible for meeting permit limits.

There were no problems with the analytical events associated with this report unless noted in the Case Narrative. Analytical results designated with a "J" qualifier are estimated and represent a detection above the Method Detection Limit (MDL or LOD) and less than the Reporting Limit (PQL or RL). These analytes are not reviewed nor narrated as to whether they are laboratory artifacts.

Quality control data is within laboratory defined or method specified acceptance limits except if noted on the case narrative.

If you have any questions regarding these tests results, please feel free to call.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401

CC:
Kim Patten



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: **1607708**

Date: **8/15/2016**

CLIENT: Corvallis School District

Project: Linus Pauling MS

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed ALG lab report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program.

All QA/QC requirements were met except as noted below.

Analytical comments are noted with data flags on the reports and/or below.

WO#: 1607708
CLIENT: Corvallis School District
Project: Linus Pauling MS
PWS Number:
Sample Source:

Received Date: 7/15/2016 10:36:00 AM
Sampler Name Paul Jennison
Matrix: Drinking Water
Sample Type:

Lab ID: 1607708-001 **Client Sample ID** LP-213-DF-#1 **Collection Date:** 7/12/2016 5:01:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 3:20:00 PM	PG

Lab ID: 1607708-002 **Client Sample ID** LP-213-F-#1 **Collection Date:** 7/12/2016 5:01:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 3:20:00 PM	PG

Lab ID: 1607708-003 **Client Sample ID** LP-216-F-#1 **Collection Date:** 7/12/2016 4:59:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 3:20:00 PM	PG

Lab ID: 1607708-004 **Client Sample ID** LP-216-DF-#1 **Collection Date:** 7/12/2016 4:59:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 3:20:00 PM	PG

Lab ID: 1607708-005 **Client Sample ID** LP-215-DF-#1 **Collection Date:** 7/12/2016 4:59:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 3:20:00 PM	PG

Lab ID: 1607708-006 **Client Sample ID** LP-215-F-#1 **Collection Date:** 7/12/2016 4:59:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 3:20:00 PM	PG

Lab ID: 1607708-007 **Client Sample ID** LP-218-F-#1 **Collection Date:** 7/12/2016 4:59:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 3:20:00 PM	PG

Lab ID: 1607708-008 **Client Sample ID** LP-218-DF-#1 **Collection Date:** 7/12/2016 4:59:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 3:20:00 PM	PG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1607708
CLIENT: Corvallis School District
Project: Linus Pauling MS
PWS Number:
Sample Source:

Received Date: 7/15/2016 10:36:00 AM
Sampler Name: Paul Jennison
Matrix: Drinking Water
Sample Type:

Lab ID: 1607708-009 **Client Sample ID** LP-217-F-#1 **Collection Date:** 7/12/2016 4:57:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 3:20:00 PM	PG

Lab ID: 1607708-010 **Client Sample ID** LP-217-DF-#1 **Collection Date:** 7/12/2016 4:57:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 3:20:00 PM	PG

Lab ID: 1607708-011 **Client Sample ID** LP-202-F-#1 **Collection Date:** 7/12/2016 5:07:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 3:20:00 PM	PG

Lab ID: 1607708-012 **Client Sample ID** LP-2FIMidHallE-DF-#1 **Collection Date:** 7/12/2016 5:06:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 3:20:00 PM	PG

Lab ID: 1607708-013 **Client Sample ID** LP-Staffirm-F-#1 **Collection Date:** 7/12/2016 5:05:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 3:20:00 PM	PG

Lab ID: 1607708-014 **Client Sample ID** LP-2F1-MidHallW-DF-#1 **Collection Date:** 7/12/2016 5:04:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 3:20:00 PM	PG

Lab ID: 1607708-015 **Client Sample ID** LP-212A-F-#1 **Collection Date:** 7/12/2016 5:03:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 3:20:00 PM	PG

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit

WO#: 1607708
CLIENT: Corvallis School District
Project: Linus Pauling MS
PWS Number:
Sample Source:

Received Date: 7/15/2016 10:36:00 AM
Sampler Name: Paul Jennison
Matrix: Drinking Water
Sample Type:

Lab ID: 1607708-016 **Client Sample ID:** LP-212-DF-#1 **Collection Date:** 7/12/2016 5:03:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 3:20:00 PM	PG

Lab ID: 1607708-017 **Client Sample ID:** LP-212-F-#1 **Collection Date:** 7/12/2016 5:03:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 3:20:00 PM	PG

Lab ID: 1607708-018 **Client Sample ID:** LP-2F1-WHall-DF-#1 **Collection Date:** 7/12/2016 5:02:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 3:20:00 PM	PG

Lab ID: 1607708-019 **Client Sample ID:** LP-214-DF-#1 **Collection Date:** 7/12/2016 5:01:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 3:20:00 PM	PG

Lab ID: 1607708-020 **Client Sample ID:** LP-214-F-#1 **Collection Date:** 7/12/2016 5:01:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 3:20:00 PM	PG

Lab ID: 1607708-021 **Client Sample ID:** LP-211-DF-#1 **Collection Date:** 7/12/2016 5:14:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 9:31:00 PM	SN

Lab ID: 1607708-022 **Client Sample ID:** LP-211-F-#1 **Collection Date:** 7/12/2016 5:14:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 9:31:00 PM	SN

Lab ID: 1607708-023 **Client Sample ID:** LP-210-DF-#1 **Collection Date:** 7/12/2016 5:15:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 9:31:00 PM	SN

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit

WO#: 1607708
CLIENT: Corvallis School District
Project: Linus Pauling MS
PWS Number:
Sample Source:

Received Date: 7/15/2016 10:36:00 AM
Sampler Name: Paul Jennison
Matrix: Drinking Water
Sample Type:

Lab ID: 1607708-024 **Client Sample ID** LP-210-F-#1 **Collection Date:** 7/12/2016 5:15:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 9:31:00 PM	SN

Lab ID: 1607708-025 **Client Sample ID** LP-2FIEHall-DF-#1 **Collection Date:** 7/12/2016 5:13:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 9:31:00 PM	SN

Lab ID: 1607708-026 **Client Sample ID** LP-208-F-#1 **Collection Date:** 7/12/2016 5:12:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 9:31:00 PM	SN

Lab ID: 1607708-027 **Client Sample ID** LP-208-DF-#1 **Collection Date:** 7/12/2016 5:12:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 9:31:00 PM	SN

Lab ID: 1607708-028 **Client Sample ID** LP-209-DF-#1 **Collection Date:** 7/12/2016 5:12:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 9:31:00 PM	SN

Lab ID: 1607708-029 **Client Sample ID** LP-209-F-#1 **Collection Date:** 7/12/2016 5:12:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 9:31:00 PM	SN

Lab ID: 1607708-030 **Client Sample ID** LP-207-DF-#1 **Collection Date:** 7/12/2016 5:11:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 9:31:00 PM	SN

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit

WO#: 1607708
CLIENT: Corvallis School District
Project: Linus Pauling MS
PWS Number:
Sample Source:

Received Date: 7/15/2016 10:36:00 AM
Sampler Name: Paul Jennison
Matrix: Drinking Water
Sample Type:

Lab ID: 1607708-031 **Client Sample ID:** LP-207-F-#1 **Collection Date:** 7/12/2016 5:11:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 9:31:00 PM	SN

Lab ID: 1607708-032 **Client Sample ID:** LP-206-F-#1 **Collection Date:** 7/12/2016 5:10:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 9:31:00 PM	SN

Lab ID: 1607708-033 **Client Sample ID:** LP-206-DF-#1 **Collection Date:** 7/12/2016 5:10:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 9:31:00 PM	SN

Lab ID: 1607708-034 **Client Sample ID:** LP-205-F-#1 **Collection Date:** 7/12/2016 5:10:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 9:31:00 PM	SN

Lab ID: 1607708-035 **Client Sample ID:** LP-205-DF-#1 **Collection Date:** 7/12/2016 5:10:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 9:31:00 PM	SN

Lab ID: 1607708-036 **Client Sample ID:** LP-203-DF-#1 **Collection Date:** 7/12/2016 5:08:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 9:31:00 PM	SN

Lab ID: 1607708-037 **Client Sample ID:** LP-203-F-#1 **Collection Date:** 7/12/2016 5:08:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 9:31:00 PM	SN

Lab ID: 1607708-038 **Client Sample ID:** LP-201-F-#1 **Collection Date:** 7/12/2016 5:08:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 9:31:00 PM	SN

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



WO#: 1607708
CLIENT: Corvallis School District
Project: Linus Pauling MS
PWS Number:
Sample Source:

Received Date: 7/15/2016 10:36:00 AM
Sampler Name: Paul Jennison
Matrix: Drinking Water
Sample Type:

Lab ID: 1607708-039 **Client Sample ID** LP-201-DF-#1 **Collection Date:** 7/12/2016 5:08:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 9:31:00 PM	SN

Lab ID: 1607708-040 **Client Sample ID** LP-202-DF-#1 **Collection Date:** 7/12/2016 5:07:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 9:31:00 PM	SN

Lab ID: 1607708-041 **Client Sample ID** LP-102-DF-#1 **Collection Date:** 7/12/2016 5:23:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 9:31:00 PM	SN

Lab ID: 1607708-042 **Client Sample ID** LP-104-DF-#1 **Collection Date:** 7/12/2016 5:20:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 9:31:00 PM	SN

Lab ID: 1607708-043 **Client Sample ID** LP-104-F-#1 **Collection Date:** 7/12/2016 5:20:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 9:31:00 PM	SN

Lab ID: 1607708-044 **Client Sample ID** LP-103-F-#1 **Collection Date:** 7/12/2016 5:23:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/10/2016 9:31:00 PM	SN

Lab ID: 1607708-045 **Client Sample ID** LP-102-F-#1 **Collection Date:** 7/12/2016 5:23:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/11/2016 5:45:00 PM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Analytical Report

Date Reported 8/15/2016

WO#: 1607708
CLIENT: Corvallis School District
Project: Linus Pauling MS
PWS Number:
Sample Source:

Received Date: 7/15/2016 10:36:00 AM
Sampler Name: Paul Jennison
Matrix: Drinking Water
Sample Type:

Lab ID: 1607708-046 **Client Sample ID** LP-101-F-#1 **Collection Date:** 7/12/2016 5:20:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/11/2016 5:45:00 PM	KG

Lab ID: 1607708-047 **Client Sample ID** LP-101-DF-#1 **Collection Date:** 7/12/2016 5:20:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	8/11/2016 5:45:00 PM	KG

Lab ID: 1607708-048 **Client Sample ID** LP-ArtRmNWF-#1 **Collection Date:** 7/12/2016 5:47:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00480	0.0200	0.00200		mg/L	8/11/2016 5:45:00 PM	KG

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

**Accreditation Program
 Analytes Report**
 WO#: 1607708
 15-Aug-16

Client: Corvallis School District
Project: Linus Pauling MS

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1607708-001A	LP-213-DF-#1	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1607708-002A	LP-213-F-#1			Lead	A
	1607708-003A	LP-216-F-#1			Lead	A
	1607708-004A	LP-216-DF-#1			Lead	A
	1607708-005A	LP-215-DF-#1			Lead	A
	1607708-006A	LP-215-F-#1			Lead	A
	1607708-007A	LP-218-F-#1			Lead	A
	1607708-008A	LP-218-DF-#1			Lead	A
	1607708-009A	LP-217-F-#1			Lead	A
	1607708-010A	LP-217-DF-#1			Lead	A
	1607708-011A	LP-202-F-#1			Lead	A
	1607708-012A	LP-2FlMidHallE- DF-#1			Lead	A
	1607708-013A	LP-Staffrm-F-#1			Lead	A
	1607708-014A	LP-2F1-MidHallW- DF-#1			Lead	A
	1607708-015A	LP-212A-F-#1			Lead	A
	1607708-016A	LP-212-DF-#1			Lead	A
	1607708-017A	LP-212-F-#1			Lead	A
	1607708-018A	LP-2Fl-WHall-DF- #1			Lead	A
	1607708-019A	LP-214-DF-#1			Lead	A
	1607708-020A	LP-214-F-#1			Lead	A
	1607708-021A	LP-211-DF-#1			Lead	A
	1607708-022A	LP-211-F-#1			Lead	A
	1607708-023A	LP-210-DF-#1			Lead	A
	1607708-024A	LP-210-F-#1			Lead	A
	1607708-025A	LP-2FlEHall-DF-#1			Lead	A
	1607708-026A	LP-208-F-#1			Lead	A
	1607708-027A	LP-208-DF-#1			Lead	A
	1607708-028A	LP-209-DF-#1			Lead	A
	1607708-029A	LP-209-F-#1			Lead	A
	1607708-030A	LP-207-DF-#1			Lead	A

ACCRED ORELAP A Accredited



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 1607708

15-Aug-16

Client: Corvallis School District

Project: Linus Pauling MS

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1607708-031A	LP-207-F-#1	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1607708-032A	LP-206-F-#1			Lead	A
	1607708-033A	LP-206-DF-#1			Lead	A
	1607708-034A	LP-205-F-#1			Lead	A
	1607708-035A	LP-205-DF-#1			Lead	A
	1607708-036A	LP-203-DF-#1			Lead	A
	1607708-037A	LP-203-F-#1			Lead	A
	1607708-038A	LP-201-F-#1			Lead	A
	1607708-039A	LP-201-DF-#1			Lead	A
	1607708-040A	LP-202-DF-#1			Lead	A
	1607708-041A	LP-102-DF-#1			Lead	A
	1607708-042A	LP-104-DF-#1			Lead	A
	1607708-043A	LP-104-F-#1			Lead	A
	1607708-044A	LP-103-F-#1			Lead	A
	1607708-045A	LP-102-F-#1			Lead	A
	1607708-046A	LP-101-F-#1			Lead	A
	1607708-047A	LP-101-DF-#1			Lead	A
	1607708-048A	LP-ArtRmNWF-#1			Lead	A

ORELAP A Accredited

ACCRED

Original #1607708# v1

Page 11 of 13



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 1607708

Date: 8/15/2016

Definitions:

% REC: Percent Recovery; a measure of accuracy expressed as a percentage of a measured (recovered) concentration compared to the known concentration added to the sample.

% RPD: Relative Percent Difference; a measure of precision expressed as a percentage of the difference between two duplicates relative to the average concentration.

DF: Dilution factor; the dilution factor applied to the prepared sample.

DUP: Duplicate; aliquots of a sample taken from the same container under laboratory conditions and processed and analyzed independently, used to calculate Precision (%RPD).

LCS: Laboratory Control Sample; prepared by adding a known mass of target analytes to a specified amount of de-ionized water and prepared with the batch of samples, used to calculate Accuracy (%REC).

LCSD: The duplicate sample of the LCS, used to calculate both Accuracy (%REC) and Precision (%RPD)

MBLK: Method Blank; a sample of similar matrix that is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedure, and in which no target analytes or interferences are present at concentrations that impact the analytical results for sample analyses.

MS: Matrix Spike; prepared by adding a known mass of target analytes to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available, used to calculate Accuracy (%REC)

MSD: The duplicate sample of the MS, used to calculate both Accuracy (%REC) and Precision (%RPD)

ND: Not Detected. The analyte level is below the lowest point the laboratory can test for.

PL: Permit limit; only applicable to wastewater reports.

PQL: Practical Quantitation Level or Reporting Limit; the limit to which data is compared for reporting.

Qual: Qualifier that applies to the analyte reported

Original

Page 12 of 13



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 1607708

Date: 8/15/2016

Definitions:

Result: Analyte concentration reported

RL: Reporting Limit/Limit of Quantitation; the limit to which data is compared for reporting. Analyte concentrations below the reporting limit are reported as ND or with a “J” qualifier.

Units: The units in which the analyte concentration is reported.

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
R	RPD outside accepted recovery limits
RL	Reporting Detection Limit
U	Samples with CalcVal < MDL
W	Sample container temperature is out of limit as specified at testcode

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: paul.jennison@corvallis.k12.or.us	City, State, Zip: Corvallis, OR 97333

Client Project: Linus Pauling MS	Sampler: Print <i>PAUL JENNISON</i>	Sampler: Signature <i>[Signature]</i>
----------------------------------	--	--

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
LP-213-DF-#1	DW/Grab	07-12-16	5:01am	Lead	P	1			001A
LP-213-F-#1	DW/Grab		5:01am	Lead	P	1			002A
LP-216-F-#1	DW/Grab		4:59am	Lead	P	1			003A
LP-216-DF-#1	DW/Grab		4:59am	Lead	P	1			004A
LP-215-DF-#1	DW/Grab		4:59am	Lead	P	1			005A
LP-215-F-#1	DW/Grab		4:59am	Lead	P	1			006A
LP-218-F-#1	DW/Grab	07-12-16	4:59am	Lead	P	1			007A
LP-218-DF-#1	DW/Grab	07-12-16	4:59am	Lead	P	1			008A
LP-217-F-#1	DW/Grab	07-12-16	4:57am	Lead	P	1			009A
LP-217-DF-#1	DW/Grab	07-12-16	4:57am	Lead	P	1			010A

Notes:	<table border="1" style="width:100%"> <thead> <tr> <th colspan="5">Preservation Check</th> </tr> <tr> <th>Lab ID</th> <th>Date/Time</th> <th>Pre-Preserved</th> <th>pH</th> <th>Tech</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	Preservation Check					Lab ID	Date/Time	Pre-Preserved	pH	Tech																																													
Preservation Check																																																								
Lab ID	Date/Time	Pre-Preserved	pH	Tech																																																				

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: ALG COURIER	Refrigerated: NA
---	--------------------------	------------------

Relinquished by:	Date	Time	Received by:	Date	Time
			<i>[Signature]</i>	7/15/16	0905
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<i>[Signature]</i>	7/15/16	1036	<i>[Signature]</i>	7/15/16	1036

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com



CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: paul.jennison@corvallis.k12.or.us	City, State, Zip: Corvallis, OR 97333
Client Project: Linus Pauling MS	Sampler: Print PAUL JENNISON
	Sampler: Signature <i>[Signature]</i>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
LP-202-F-#1	DW/Grab	7/12/16	5:07am	Lead	P	1			011A
LP-2FI MidHallE-DF-#1	DW/Grab	}	5:08am	Lead	P	1			012A
LP-staffRM-F-#1	DW/Grab		5:05am	Lead	P	1			013A
LP-2FI MidHallW-DF-#1	DW/Grab		5:04am	Lead	P	1			014A
LP-212A-F-#1	DW/Grab		5:03am	Lead	P	1			015A
LP-212-DF-#1	DW/Grab		5:03am	Lead	P	1			016A
LP-213-F-#1	DW/Grab		5:03am	Lead	P	1			017A
LP-2FI-WHall-DF-#1	DW/Grab		5:02am	Lead	P	1			018A
LP-214-DF-#1	DW/Grab		5:01am	Lead	P	1			019A
LP-214-F-#1	DW/Grab		5:01am	Lead	P	1			020A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: ALG COURIER	Refrigerated
---	-----------------------------	--------------

Relinquished by:	Date	Time	Received by:	Date	Time
<i>[Signature]</i>	7/15/16	1036	<i>[Signature]</i>	7/15/16	0905
Relinquished by:	Date	Time	Received by:	Date	Time
<i>[Signature]</i>	7/15/16	1036	<i>[Signature]</i>	7/15/16	1036
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<i>[Signature]</i>	7/15/16	1036	<i>[Signature]</i>	7/15/16	1036

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com



CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: paul.jennison@corvallis.k12.or.us	City, State, Zip: Corvallis, OR 97333
Client Project: Linus Pauling MS	Sampler: Print <i>PAUL JENNISON</i>
	Sampler: Signature <i>[Signature]</i>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
LP-211-DF-#1	DW/Grab	6-24-16	5:14am	Lead	P	1			021A
LP-211-F-#1	DW/Grab		5:14am	Lead	P	1			022A
LP-210-DF-#1	DW/Grab		5:15am	Lead	P	1			023A
LP-210-F-#1	DW/Grab		5:15am	Lead	P	1			024A
LP-2FL E Hall-DF-#1	DW/Grab		5:13am	Lead	P	1			025A
LP-208-P-#1	DW/Grab		5:12am	Lead	P	1			026A
LP-208-DF-#1	DW/Grab		5:12am	Lead	P	1			027A
LP-209-DF-#1	DW/Grab		5:12am	Lead	P	1			028A
LP-209-F-#1	DW/Grab		5:12am	Lead	P	1			029A
LP-207-DF-#1	DW/Grab		5:11am	Lead	P	1			030A

Notes:	<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th colspan="5">Preservation Check</th> </tr> <tr> <th>Lab ID</th> <th>Date/Time</th> <th>Pre-Preserved</th> <th>pH</th> <th>Tech</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	Preservation Check					Lab ID	Date/Time	Pre-Preserved	pH	Tech																																													
Preservation Check																																																								
Lab ID	Date/Time	Pre-Preserved	pH	Tech																																																				

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: ALG COURIER	Refrigerated NA			
Relinquished by:	Date	Time	Received by:	Date	Time
			<i>[Signature]</i>	7/15/16	0905
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<i>[Signature]</i>	7/15/16	1036	<i>[Signature]</i>	7/15/16	1036

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: paul.jennison@corvallis.k12.or.us	City, State, Zip: Corvallis, OR 97333
Client Project: Linus Pauling MS	Sampler: Print <i>PAUL JENNISON</i>
	Sampler: Signature <i>[Signature]</i>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
LP-207-F-#1	DW/Grab	7/15/16	5:11am	Lead	P	1			031A
LP-206-F-#1	DW/Grab		5:10am	Lead	P	1			032A
LP-206-DF-#1	DW/Grab		5:10am	Lead	P	1			033A
LP-205-F-#1	DW/Grab		5:10am	Lead	P	1			034A
LP-205-DF-#1	DW/Grab		5:10am	Lead	P	1			035A
LP-203-DF-#1	DW/Grab		5:09am	Lead	P	1			036A
LP-203-F-#1	DW/Grab		5:08am	Lead	P	1			037A
LP-201-F-#1	DW/Grab		5:08am	Lead	P	1			038A
LP-201-DF-#1	DW/Grab		5:08am	Lead	P	1			039A
LP-202-DF-#1	DW/Grab		5:08am	Lead	P	1			040A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge):	Shipped Via:	Refrigerated
<input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	ALG COURIER	NA

Relinquished by:	Date	Time	Received by:	Date	Time
<i>[Signature]</i>			<i>[Signature]</i>	7/15/16	0905
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<i>[Signature]</i>	7/15/16	1036	<i>[Signature]</i>	7/15/16	1036

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: paul.jennison@corvallis.k12.or.us	City, State, Zip: Corvallis, OR 97333
Client Project: Linus Pauling MS	Sampler: Print PAUL JENNISON
	Sampler: Signature

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
LP-102-DF-#1	DW/Grab	07-12-16	6:23am	Lead	P	1			041A
LP-104-DF-#1	DW/Grab	}	6:20am	Lead	P	1			042A
LP-104-F-#1	DW/Grab		6:20am	Lead	P	1			043A
LP-103-F-#1	DW/Grab		6:23am	Lead	P	1			044A
LP-102-F-#1	DW/Grab		6:23am	Lead	P	1			045A
LP-101-F-#1	DW/Grab		6:20am	Lead	P	1			046A
LP-101-DF-#1	DW/Grab		6:20am	Lead	P	1			047A
LP-ASTRMWVF#1	DW/Grab		6:47am	Lead	P	1			048A
	DW/Grab				Lead	P	1		
	DW/Grab			Lead	P	1			

Notes:	<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th colspan="5">Preservation Check</th> </tr> <tr> <th>Lab ID</th> <th>Date/Time</th> <th>Pre-Preserved</th> <th>pH</th> <th>Tech</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	Preservation Check					Lab ID	Date/Time	Pre-Preserved	pH	Tech																																								
Preservation Check																																																			
Lab ID	Date/Time	Pre-Preserved	pH	Tech																																															

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL _____ <input type="checkbox"/> RUSH _____	Shipped Via: ALG COURIER	Refrigerated NA
---	-----------------------------	--------------------

Relinquished by:	Date	Time	Received by:	Date	Time
				7/15/16	0905
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
	7/15/16	1036		7/15/16	1036