



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

August 05, 2016

Paul Jennison
Corvallis School District
P O Box 3509J
Corvallis, OR 97339
TEL: (541) 757-5853
FAX

RE: Garfield Ele.

Order No.: 1607377

Dear Paul Jennison:

Analytical Laboratory Group received 47 sample(s) on 7/8/2016 for the analyses presented in the following report.

The analysis was performed according to our laboratory's NELAP/TNI-approved quality assurance program. Any exceptions to this quality assurance program are noted on the case narrative.

Testing methods used are sufficiently sensitive enough to meet the requirements that support client/permittee NPDES permits that we have on file. The client is responsible for reviewing reports. The permittee is responsible for meeting permit limits.

There were no problems with the analytical events associated with this report unless noted in the Case Narrative. Analytical results designated with a "J" qualifier are estimated and represent a detection above the Method Detection Limit (MDL or LOD) and less than the Reporting Limit (PQL or RL). These analytes are not reviewed nor narrated as to whether they are laboratory artifacts.

Quality control data is within laboratory defined or method specified acceptance limits except if noted on the case narrative.

If you have any questions regarding these tests results, please feel free to call.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401

CC:
Kim Patten



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 1607377

Date: 8/5/2016

CLIENT: Corvallis School District

Project: Garfield Ele.

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed ALG lab report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program.

All QA/QC requirements were met except as noted below.

Analytical comments are noted with data flags on the reports and/or below.



WO#: 1607377
CLIENT: Corvallis School District
Project: Garfield Ele.
PWS Number:
Sample Source:

Received Date: 7/8/2016 3:10:00 PM
Sampler Name: Matt Holliday
Matrix: Drinking Water
Sample Type:

Lab ID: 1607377-001 **Client Sample ID:** GA-28-F-#1 **Collection Date:** 7/8/2016 6:08:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0357	0.0200	0.00800	*	mg/L	7/19/2016 7:44:00 AM	KG

Lab ID: 1607377-002 **Client Sample ID:** GA-KITE-F#1 **Collection Date:** 7/8/2016 6:36:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Lab ID: 1607377-003 **Client Sample ID:** GA-KITW-F-#1 **Collection Date:** 7/8/2016 6:36:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Lab ID: 1607377-004 **Client Sample ID:** GA-RRHALL-DF-#1 **Collection Date:** 7/8/2016 6:43:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Lab ID: 1607377-005 **Client Sample ID:** GA-EHALL-DF-#1 **Collection Date:** 7/8/2016 5:58:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Lab ID: 1607377-006 **Client Sample ID:** GA-GYMHALL-DF-#1 **Collection Date:** 7/8/2016 5:59:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Lab ID: 1607377-007 **Client Sample ID:** GA-HLTH-F-#1 **Collection Date:** 7/8/2016 6:15:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00275	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Lab ID: 1607377-008 **Client Sample ID:** GA-WKRM-F-#1 **Collection Date:** 7/8/2016 6:17:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00745	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1607377
CLIENT: Corvallis School District
Project: Garfield Ele.
PWS Number:
Sample Source:

Received Date: 7/8/2016 3:10:00 PM
Sampler Name: Matt Holliday
Matrix: Drinking Water
Sample Type:

Lab ID: 1607377-009 **Client Sample ID:** GA-KITIS-F-#1 **Collection Date:** 7/8/2016 6:18:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG
------	-----------	----	--------	---------	--	------	----------------------	----

Lab ID: 1607377-010 **Client Sample ID:** GA-16-F-#1 **Collection Date:** 7/8/2016 5:53:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	0.0163	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG
------	-----------	--------	--------	---------	--	------	----------------------	----

Lab ID: 1607377-011 **Client Sample ID:** GA-16-DF-#1 **Collection Date:** 7/8/2016 5:53:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG
------	-----------	----	--------	---------	--	------	----------------------	----

Lab ID: 1607377-012 **Client Sample ID:** GA-17-F-#1 **Collection Date:** 7/8/2016 5:51:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	0.106	0.0200	0.0200	*	mg/L	7/19/2016 7:44:00 AM	KG
------	-----------	-------	--------	--------	---	------	----------------------	----

Lab ID: 1607377-013 **Client Sample ID:** GA-17-DF-#1 **Collection Date:** 7/8/2016 5:51:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	0.00482	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG
------	-----------	---------	--------	---------	--	------	----------------------	----

Lab ID: 1607377-014 **Client Sample ID:** GA-18-F-#1 **Collection Date:** 7/8/2016 5:49:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	0.0104	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG
------	-----------	--------	--------	---------	--	------	----------------------	----

Lab ID: 1607377-015 **Client Sample ID:** GA-18-DF-#1 **Collection Date:** 7/8/2016 5:49:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	0.00535	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG
------	-----------	---------	--------	---------	--	------	----------------------	----

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1607377
CLIENT: Corvallis School District
Project: Garfield Ele.
PWS Number:
Sample Source:

Received Date: 7/8/2016 3:10:00 PM
Sampler Name: Matt Holliday
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID	GA-CAF-DF-#1	Collection Date:	7/8/2016 6:41:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Lab ID:	Client Sample ID	GA-GYM-DF-#1	Collection Date:	7/8/2016 5:57:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00381	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Lab ID:	Client Sample ID	GA-19-F-#1	Collection Date:	7/8/2016 5:47:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0212	0.0200	0.00400	*	mg/L	7/19/2016 7:44:00 AM	KG

Lab ID:	Client Sample ID	GA-27-F-#1	Collection Date:	7/8/2016 6:45:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00543	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Lab ID:	Client Sample ID	GA-11-F-#1	Collection Date:	7/8/2016 6:05:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0572	0.0200	0.00800	*	mg/L	7/19/2016 7:44:00 AM	KG

Lab ID:	Client Sample ID	GA-11-DF-#1	Collection Date:	7/8/2016 6:04:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0126	0.0200	0.00200		mg/L	7/19/2016 5:37:00 PM	SN

Lab ID:	Client Sample ID	GA-12-F-#1	Collection Date:	7/8/2016 6:03:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0149	0.0200	0.00200		mg/L	7/19/2016 5:37:00 PM	SN

Lab ID:	Client Sample ID	GA-12-DF-#1	Collection Date:	7/8/2016 6:02:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00430	0.0200	0.00200		mg/L	7/19/2016 5:37:00 PM	SN

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1607377
CLIENT: Corvallis School District
Project: Garfield Ele.
PWS Number:
Sample Source:

Received Date: 7/8/2016 3:10:00 PM
Sampler Name: Matt Holliday
Matrix: Drinking Water
Sample Type:

Lab ID: 1607377-024 **Client Sample ID:** GA-13-F-#1 **Collection Date:** 7/8/2016 6:06:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00427	0.0200	0.00200		mg/L	7/19/2016 5:37:00 PM	SN

Lab ID: 1607377-025 **Client Sample ID:** GA-13-DF-#1 **Collection Date:** 7/8/2016 6:06:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00581	0.0200	0.00200		mg/L	7/19/2016 5:37:00 PM	SN

Lab ID: 1607377-026 **Client Sample ID:** GA-14-F-#1 **Collection Date:** 7/8/2016 6:01:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0256	0.0200	0.00400	*	mg/L	7/19/2016 5:37:00 PM	SN

Lab ID: 1607377-027 **Client Sample ID:** GA-14-DF-#1 **Collection Date:** 7/8/2016 6:00:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0217	0.0200	0.00400	*	mg/L	7/19/2016 5:37:00 PM	SN

Lab ID: 1607377-028 **Client Sample ID:** GA-15-F-#1 **Collection Date:** 7/8/2016 5:55:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0110	0.0200	0.00200		mg/L	7/19/2016 5:37:00 PM	SN

Lab ID: 1607377-029 **Client Sample ID:** GA-15-DF-#1 **Collection Date:** 7/8/2016 5:55:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00486	0.0200	0.00200		mg/L	7/19/2016 5:37:00 PM	SN

Lab ID: 1607377-030 **Client Sample ID:** GA-6-F-#1 **Collection Date:** 7/8/2016 6:24:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00561	0.0200	0.00200		mg/L	7/19/2016 5:37:00 PM	SN

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1607377
CLIENT: Corvallis School District
Project: Garfield Ele.
PWS Number:
Sample Source:

Received Date: 7/8/2016 3:10:00 PM
Sampler Name: Matt Holliday
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID	GA-6-DF-#1	Collection Date:	7/8/2016 6:28:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00480	0.0200	0.00200		mg/L	7/19/2016 5:37:00 PM	SN

Lab ID:	Client Sample ID	GA-7-F-#1	Collection Date:	7/8/2016 6:23:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00523	0.0200	0.00200		mg/L	7/19/2016 5:37:00 PM	SN

Lab ID:	Client Sample ID	GA-7-DF-#1	Collection Date:	7/8/2016 6:22:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00459	0.0200	0.00200		mg/L	7/19/2016 5:37:00 PM	SN

Lab ID:	Client Sample ID	GA-8-F-#1	Collection Date:	7/8/2016 6:20:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/19/2016 5:37:00 PM	SN

Lab ID:	Client Sample ID	GA-8-DF-#1	Collection Date:	7/8/2016 6:20:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00394	0.0200	0.00200		mg/L	7/19/2016 5:37:00 PM	SN

Lab ID:	Client Sample ID	GA-9-F-#1	Collection Date:	7/8/2016 6:13:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00613	0.0200	0.00200		mg/L	7/19/2016 5:37:00 PM	SN

Lab ID:	Client Sample ID	GA-9-DF-#1	Collection Date:	7/8/2016 6:13:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00491	0.0200	0.00200		mg/L	7/19/2016 5:37:00 PM	SN

Lab ID:	Client Sample ID	GA-10-F-#1	Collection Date:	7/8/2016 6:12:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00639	0.0200	0.00200		mg/L	7/19/2016 5:37:00 PM	SN

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1607377
CLIENT: Corvallis School District
Project: Garfield Ele.
PWS Number:
Sample Source:

Received Date: 7/8/2016 3:10:00 PM
Sampler Name: Matt Holliday
Matrix: Drinking Water
Sample Type:

Lab ID: 1607377-039 **Client Sample ID:** GA-10-DF-#1 **Collection Date:** 7/8/2016 6:12:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00393	0.0200	0.00200		mg/L	7/19/2016 5:37:00 PM	SN

Lab ID: 1607377-040 **Client Sample ID:** GA-2-F-#1 **Collection Date:** 7/8/2016 6:32:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00346	0.0200	0.00200		mg/L	7/19/2016 5:37:00 PM	SN

Lab ID: 1607377-041 **Client Sample ID:** GA-2-DF-#1 **Collection Date:** 7/8/2016 6:32:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00472	0.0200	0.00200		mg/L	7/19/2016 5:37:00 PM	SN

Lab ID: 1607377-042 **Client Sample ID:** GA-3-F-#1 **Collection Date:** 7/8/2016 6:34:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/19/2016 5:37:00 PM	SN

Lab ID: 1607377-043 **Client Sample ID:** GA-3-DF-#1 **Collection Date:** 7/8/2016 6:33:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00347	0.0200	0.00200		mg/L	7/19/2016 5:37:00 PM	SN

Lab ID: 1607377-044 **Client Sample ID:** GA-4-F-#1 **Collection Date:** 7/8/2016 6:29:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00397	0.0200	0.00200		mg/L	7/19/2016 5:37:00 PM	SN

Lab ID: 1607377-045 **Client Sample ID:** GA-4-DF-#1 **Collection Date:** 7/8/2016 6:28:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00559	0.0200	0.00200		mg/L	7/19/2016 5:37:00 PM	SN

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Analytical Report

Date Reported **8/5/2016**

WO#: 1607377
CLIENT: Corvallis School District
Project: Garfield Ele.
PWS Number:
Sample Source:

Received Date: 7/8/2016 3:10:00 PM
Sampler Name: Matt Holliday
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID			Collection Date:			
1607377-046	GA-5-F-#1			7/8/2016 6:26:00 AM			
Analyses	Method	Result	MCL	RL Qual Units	Date Analyzed	Analys	
Lead	SM 3113 B	0.0149	0.0200	0.00200	mg/L	7/19/2016 5:37:00 PM	SN

Lab ID:	Client Sample ID			Collection Date:			
1607377-047	GA-5-DF-#1			7/8/2016 6:26:00 AM			
Analyses	Method	Result	MCL	RL Qual Units	Date Analyzed	Analys	
Lead	SM 3113 B	0.137	0.0200	0.0200 *	mg/L	7/19/2016 5:37:00 PM	SN

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program Analytes Report

WO#: 1607377
 05-Aug-16

Client: Corvallis School District
Project: Garfield Ele.

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1607377-001A	GA-28-F-#1	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1607377-002A	GA-KITE-F#1			Lead	A
	1607377-003A	GA-KITW-F-#1			Lead	A
	1607377-004A	GA-RRHALL-DF- #1			Lead	A
	1607377-005A	GA-EHALL-DF-#1			Lead	A
	1607377-006A	GA-GYMHALL- DF-#1			Lead	A
	1607377-007A	GA-HLTH-F-#1			Lead	A
	1607377-008A	GA-WKRM-F-#1			Lead	A
	1607377-009A	GA-KITIS-F-#1			Lead	A
	1607377-010A	GA-16-F-#1			Lead	A
	1607377-011A	GA-16-DF-#1			Lead	A
	1607377-012A	GA-17-F-#1			Lead	A
	1607377-013A	GA-17-DF-#1			Lead	A
	1607377-014A	GA-18-F-#1			Lead	A
	1607377-015A	GA-18-DF-#1			Lead	A
	1607377-016A	GA-CAF-DF-#1			Lead	A
	1607377-017A	GA-GYM-DF-#1			Lead	A
	1607377-018A	GA-19-F-#1			Lead	A
	1607377-019A	GA-27-F-#1			Lead	A
	1607377-020A	GA-11-F-#1			Lead	A
	1607377-021A	GA-11-DF-#1			Lead	A
	1607377-022A	GA-12-F-#1			Lead	A
	1607377-023A	GA-12-DF-#1			Lead	A
	1607377-024A	GA-13-F-#1			Lead	A
	1607377-025A	GA-13-DF-#1			Lead	A
	1607377-026A	GA-14-F-#1			Lead	A
	1607377-027A	GA-14-DF-#1			Lead	A
	1607377-028A	GA-15-F-#1			Lead	A
	1607377-029A	GA-15-DF-#1			Lead	A
	1607377-030A	GA-6-F-#1			Lead	A

ACCRED ORELAP A Accredited



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

**Accreditation Program
 Analytes Report**

WO#: 1607377
 05-Aug-16

Client: Corvallis School District
Project: Garfield Ele.

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1607377-031A	GA-6-DF-#1	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1607377-032A	GA-7-F-#1			Lead	A
	1607377-033A	GA-7-DF-#1			Lead	A
	1607377-034A	GA-8-F-#1			Lead	A
	1607377-035A	GA-8-DF-#1			Lead	A
	1607377-036A	GA-9-F-#1			Lead	A
	1607377-037A	GA-9-DF-#1			Lead	A
	1607377-038A	GA-10-F-#1			Lead	A
	1607377-039A	GA-10-DF-#1			Lead	A
	1607377-040A	GA-2-F-#1			Lead	A
	1607377-041A	GA-2-DF-#1			Lead	A
	1607377-042A	GA-3-F-#1			Lead	A
	1607377-043A	GA-3-DF-#1			Lead	A
	1607377-044A	GA-4-F-#1			Lead	A
	1607377-045A	GA-4-DF-#1			Lead	A
	1607377-046A	GA-5-F-#1			Lead	A
	1607377-047A	GA-5-DF-#1			Lead	A

ORELAP A Accredited

ACCRED

Original #1607377# v1



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 1607377

Date: 8/5/2016

Definitions:

% REC: Percent Recovery; a measure of accuracy expressed as a percentage of a measured (recovered) concentration compared to the known concentration added to the sample.

% RPD: Relative Percent Difference; a measure of precision expressed as a percentage of the difference between two duplicates relative to the average concentration.

DF: Dilution factor; the dilution factor applied to the prepared sample.

DUP: Duplicate; aliquots of a sample taken from the same container under laboratory conditions and processed and analyzed independently, used to calculate Precision (%RPD).

LCS: Laboratory Control Sample; prepared by adding a known mass of target analytes to a specified amount of de-ionized water and prepared with the batch of samples, used to calculate Accuracy (%REC).

LCSD: The duplicate sample of the LCS, used to calculate both Accuracy (%REC) and Precision (%RPD)

MBLK: Method Blank; a sample of similar matrix that is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedure, and in which no target analytes or interferences are present at concentrations that impact the analytical results for sample analyses.

MS: Matrix Spike; prepared by adding a known mass of target analytes to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available, used to calculate Accuracy (%REC)

MSD: The duplicate sample of the MS, used to calculate both Accuracy (%REC) and Precision (%RPD)

ND: Not Detected. The analyte level is below the lowest point the laboratory can test for.

PL: Permit limit; only applicable to wastewater reports.

PQL: Practical Quantitation Level or Reporting Limit; the limit to which data is compared for reporting.

Qual: Qualifier that applies to the analyte reported



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 1607377

Date: 8/5/2016

Definitions:

Result: Analyte concentration reported

RL: Reporting Limit/Limit of Quantitation; the limit to which data is compared for reporting. Analyte concentrations below the reporting limit are reported as ND or with a “J” qualifier.

Units: The units in which the analyte concentration is reported.

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
R	RPD outside accepted recovery limits
RL	Reporting Detection Limit
U	Samples with CalcVal < MDL
W	Sample container temperature is out of limit as specified at testcode

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: paul.jennison@corvallis.k12.or.us	City, State, Zip: Corvallis, OR 97333
Client Project: Garfield Ele.	Sampler: Print Matt Holliday
	Sampler: Signature <i>Matt Holliday</i>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
GA-28-F-#1	DW/Grab	7-8-16	6:08AM	Lead	P	1			001A
GA-KITE-F-#1	DW/Grab	7-8-16	6:36AM	Lead	P	1			002A
GA-KITW-F-#1	DW/Grab	7-8-16	6:36AM	Lead	P	1			003A
GA-RRHALL-DF-#1	DW/Grab	7-8-16	6:43AM	Lead	P	1			004A
GA-EHALL-DF-#1	DW/Grab	7-8-16	5:58AM	Lead	P	1			005A
GA-GYMHALL-DF-#1	DW/Grab	7-8-16	6:59AM	Lead	P	1			006A
GA-HLTH-F-#1	DW/Grab	7-8-16	6:15AM	Lead	P	1			007A
GA-WKRM-F-#1	DW/Grab	7-8-16	6:17AM	Lead	P	1			008A
GA-KITIS-F-#	DW/Grab	7-8-16	6:38AM	Lead	P	1			009A
	DW/Grab			Lead	P	1			

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: ALG Courier	Refrigerated NA			
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
			<i>[Signature]</i>	7/8/16	1030
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<i>[Signature]</i>	7/8/16	1510	<i>[Signature]</i>	7/8/16	1510

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: paul.jennison@corvallis.k12.or.us	City, State, Zip: Corvallis, OR 97333

Client Project: <u>Garfield Ele.</u>	Sampler: Print <u>Matt Holliday</u>	Sampler: Signature <u>[Signature]</u>
--------------------------------------	--	--

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
GA-16-F-#1	DW/Grab	7-8-16	5:53am	Lead	P	1			010A
GA-16-DF-#1	DW/Grab	7-8-16	5:53am	Lead	P	1			011A
GA-17-F-#1	DW/Grab	7-8-16	5:51am	Lead	P	1			012A
GA-17-DF-#1	DW/Grab	7-8-16	5:51am	Lead	P	1			013A
GA-18-F-#1	DW/Grab	7-8-16	5:49am	Lead	P	1			014A
GA-18-DF-#1	DW/Grab	7-8-16	5:49am	Lead	P	1			015A
GA-CAF-DF-#1	DW/Grab	7-8-16	6:41am	Lead	P	1			016A
GA-GYM-DF-#1	DW/Grab	7-8-16	5:52am	Lead	P	1			017A
GA-19-F-#1	DW/Grab	7-8-16	5:47am	Lead	P	1			018A
GA-27-F-#1	DW/Grab	7-8-16	6:45am	Lead	P	1			019A

Notes:

Preservation Check				
Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: <u>ALG Courier</u>	Refrigerated <u>NA</u>
---	------------------------------------	---------------------------

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
<u>[Signature]</u>			<u>[Signature]</u>	7/8/16	1030
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<u>[Signature]</u>	7/8/16	1510	<u>[Signature]</u>	7/9/16	1510

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com



ANALYTICAL LABORATORY GROUP

CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: paul.jennison@corvallis.k12.or.us	City, State, Zip: Corvallis, OR 97333
Client Project: Garfield Ele.	Sampler: Print Matt Holliday
	Sampler: Signature <i>Matt Holliday</i>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
GA-11-F-#1	DW/Grab	7-8-16	6:05AM	Lead	P	1			020A 001A
GA-11-DF-#1	DW/Grab	7-8-16	6:06AM	Lead	P	1			021A 002A
GA-12-F-#1	DW/Grab	7-8-16	6:03AM	Lead	P	1			022A
GA-12-DF-#1	DW/Grab	7-8-16	6:02AM	Lead	P	1			023A
GA-13-F-#1	DW/Grab	7-8-16	6:06AM	Lead	P	1			024A
GA-13-DF-#1	DW/Grab	7-8-16	6:06AM	Lead	P	1			025A
GA-14-F-#1	DW/Grab	7-8-16	6:01AM	Lead	P	1			026A
GA-14-DF-#1	DW/Grab	7-8-16	6:00AM	Lead	P	1			027A
GA-15-F-#1	DW/Grab	7-8-16	5:55AM	Lead	P	1			028A
GA-15-DF-#1	DW/Grab	7-8-16	5:55AM	Lead	P	1			029A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge):		Shipped Via:		Refrigerated	
<input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH		ALG Courier		NA	
Relinquished by:	Date	Time	Received by:	Date	Time
			<i>[Signature]</i>		
Relinquished by:	Date	Time	Received by:	Date	Time
<i>[Signature]</i>	7/8/16	1510	<i>[Signature]</i>	7/8/16	1030
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<i>[Signature]</i>	7/8/16	1510	<i>[Signature]</i>	7/8/16	1510

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: paul.jennison@corvallis.k12.or.us	City, State, Zip: Corvallis, OR 97333
Client Project: Garfield Ele.	Sampler: Print Matt Holliday
	Sampler: Signature <i>[Signature]</i>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
GA-6-F-#1	DW/Grab	7-8-16	6:24am	Lead	P	1			030A
GA-6-DF-#1	DW/Grab	7-8-16	6:25am	Lead	P	1			031A
GA-7-F-#1	DW/Grab	7-8-16	6:23am	Lead	P	1			032A
GA-7-DF-#1	DW/Grab	7-8-16	6:22am	Lead	P	1			033A
GA-8-F-#1	DW/Grab	7-8-16	6:20am	Lead	P	1			034A
GA-8-DF-#1	DW/Grab	7-8-16	6:20am	Lead	P	1			035A
GA-9-F-#1	DW/Grab	7-8-16	6:13am	Lead	P	1			036A
GA-9-DF-#1	DW/Grab	7-8-16	6:13am	Lead	P	1			037A
GA-10-F-#1	DW/Grab	7-8-16	6:12am	Lead	P	1			038A
GA-10-DF-#1	DW/Grab	7-8-16	6:12am	Lead	P	1			039A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL _____ <input type="checkbox"/> RUSH _____	Shipped Via: ALG Courier	Refrigerated NA
---	-----------------------------	--------------------

Relinquished by:	Date	Time	Received by:	Date	Time
<i>[Signature]</i>			<i>[Signature]</i>		
Relinquished by:	Date	Time	Received by:	Date	Time
<i>[Signature]</i>	7/8/16	1510	<i>[Signature]</i>	7/8/16	1030
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<i>[Signature]</i>	7/8/16	1510	<i>[Signature]</i>	7/8/16	1510

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Established 1988
 100% Employee Owned

CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: paul.jennison@corvallis.k12.or.us	City, State, Zip: Corvallis, OR 97333
Client Project: Garfield Ele.	Sampler: Print Matt Holliday
	Sampler: Signature <i>Matt Holliday</i>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
GA-1-F-#1	DW/Grab			Lead	P	1			
GA-1-DF-#1	DW/Grab			Lead	P	1			
GA-2-F-#1	DW/Grab	7-8-16	6:32AM	Lead	P	1			040A
GA-2-DF-#1	DW/Grab	7-8-16	6:32AM	Lead	P	1			041A
GA-3-F-#1	DW/Grab	7-8-16	6:34AM	Lead	P	1			042A
GA-3-DF-#1	DW/Grab	7-8-16	6:33AM	Lead	P	1			043A
GA-4-F-#1	DW/Grab	7-8-16	6:29AM	Lead	P	1			044A
GA-4-DF-#1	DW/Grab	7-8-16	6:29AM	Lead	P	1			045A
GA-5-F-#1	DW/Grab	7-8-16	6:26AM	Lead	P	1			046A
GA-5-DF-#1	DW/Grab	7-8-16	6:26AM	Lead	P	1			047

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge):		Shipped Via:		Refrigerated	
<input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH		ALG Courier		NA	
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
<i>[Signature]</i>	7/8/16	1510	<i>[Signature]</i>	7/8/16	1030
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<i>[Signature]</i>	7/8/16	1510	<i>[Signature]</i>	7/8/16	1510