



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 1607371

Date: 7/18/2016

CLIENT: Corvallis School District

Project: Jefferson Ele.

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed ALG lab report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program.

All QA/QC requirements were met except as noted below.

Analytical comments are noted with data flags on the reports and/or below.

WO#: 1607371
CLIENT: Corvallis School District
Project: Jefferson Ele.
PWS Number:
Sample Source:

Received Date: 7/8/2016 3:10:00 PM
Sampler Name: Timothy Trivett
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID			Collection Date:				
1607371-001	JE-1-F-#1			7/7/2016 4:53:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00378	0.0200	0.00200		mg/L	7/15/2016 9:24:00 PM	KG

Lab ID:	Client Sample ID			Collection Date:				
1607371-002	JE-1-DF-#1			7/7/2016 4:53:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/15/2016 9:24:00 PM	KG

Lab ID:	Client Sample ID			Collection Date:				
1607371-003	JE-2-F-#1			7/7/2016 4:55:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00386	0.0200	0.00200		mg/L	7/15/2016 9:24:00 PM	KG

Lab ID:	Client Sample ID			Collection Date:				
1607371-004	JE-2-DF-#1			7/7/2016 4:55:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/15/2016 9:24:00 PM	KG

Lab ID:	Client Sample ID			Collection Date:				
1607371-005	JE-3-F-#1			7/7/2016 4:57:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0323	0.0200	0.00400	*	mg/L	7/15/2016 9:24:00 PM	KG

Lab ID:	Client Sample ID			Collection Date:				
1607371-006	JE-3-DF-#1			7/7/2016 4:57:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00324	0.0200	0.00200		mg/L	7/15/2016 9:24:00 PM	KG

Lab ID:	Client Sample ID			Collection Date:				
1607371-007	JE-4-F-#1			7/7/2016 4:59:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/15/2016 9:24:00 PM	KG

Lab ID:	Client Sample ID			Collection Date:				
1607371-008	JE-4-DF-#1			7/7/2016 4:59:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00329	0.0200	0.00200		mg/L	7/15/2016 9:24:00 PM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1607371
CLIENT: Corvallis School District
Project: Jefferson Ele.
PWS Number:
Sample Source:

Received Date: 7/8/2016 3:10:00 PM
Sampler Name Timothy Trivett
Matrix: Drinking Water
Sample Type:

Lab ID: 1607371-009 **Client Sample ID** JE-6-F-#1 **Collection Date:** 7/7/2016 5:02:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0182	0.0200	0.00200		mg/L	7/15/2016 9:24:00 PM	KG

Lab ID: 1607371-010 **Client Sample ID** JE-6-DF-#1 **Collection Date:** 7/7/2016 5:02:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00428	0.0200	0.00200		mg/L	7/15/2016 9:24:00 PM	KG

Lab ID: 1607371-011 **Client Sample ID** JE-GYM-DF-#1 **Collection Date:** 7/7/2016 5:16:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0547	0.0200	0.0200	*	mg/L	7/15/2016 9:24:00 PM	KG

Lab ID: 1607371-012 **Client Sample ID** JE-KITIS-F-#1 **Collection Date:** 7/7/2016 5:20:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0455	0.0200	0.00800	*	mg/L	7/15/2016 9:24:00 PM	KG

Lab ID: 1607371-013 **Client Sample ID** JE-KITN-F-#1 **Collection Date:** 7/7/2016 5:20:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0189	0.0200	0.00200		mg/L	7/15/2016 9:24:00 PM	KG

Lab ID: 1607371-014 **Client Sample ID** JE-KITS-F-#1 **Collection Date:** 7/7/2016 5:20:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/15/2016 9:24:00 PM	KG

Lab ID: 1607371-015 **Client Sample ID** JE-KITPF-F-#1 **Collection Date:** 7/7/2016 5:20:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	4.02	0.0200	0.800	*	mg/L	7/14/2016 2:40:00 PM	KG

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit

WO#: 1607371
CLIENT: Corvallis School District
Project: Jefferson Ele.
PWS Number:
Sample Source:

Received Date: 7/8/2016 3:10:00 PM
Sampler Name Timothy Trivett
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID	JE-HLTH-F-#1	Collection Date:	7/7/2016 5:15:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00360	0.0200	0.00200		mg/L	7/15/2016 9:24:00 PM	KG

Lab ID:	Client Sample ID	JE-WKRM-F-#1	Collection Date:	7/7/2016 5:13:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00479	0.0200	0.00200		mg/L	7/15/2016 9:24:00 PM	KG

Lab ID:	Client Sample ID	JE-PG-DF-#1	Collection Date:	7/7/2016 4:50:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00918	0.0200	0.00200		mg/L	7/15/2016 9:24:00 PM	KG

Lab ID:	Client Sample ID	JE-LIBWKRM-#1	Collection Date:	7/7/2016 5:30:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.903	0.0200	0.200	*	mg/L	7/16/2016 7:19:00 AM	KG

Lab ID:	Client Sample ID	JE-14-F-#1	Collection Date:	7/7/2016 5:35:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0155	0.0200	0.00200		mg/L	7/15/2016 9:24:00 PM	KG

Lab ID:	Client Sample ID	JE-14-DF-#1	Collection Date:	7/7/2016 5:35:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0128	0.0200	0.00200		mg/L	7/15/2016 9:24:00 PM	KG

Lab ID:	Client Sample ID	JE-16-F-#1	Collection Date:	7/7/2016 5:40:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0158	0.0200	0.00200		mg/L	7/16/2016 7:19:00 AM	KG

Lab ID:	Client Sample ID	JE-16-DF-#1	Collection Date:	7/7/2016 5:40:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0119	0.0200	0.00200		mg/L	7/16/2016 7:19:00 AM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1607371
CLIENT: Corvallis School District
Project: Jefferson Ele.
PWS Number:
Sample Source:

Received Date: 7/8/2016 3:10:00 PM
Sampler Name Timothy Trivett
Matrix: Drinking Water
Sample Type:

Lab ID: 1607371-024 **Client Sample ID** JE-17-F-#1 **Collection Date:** 7/7/2016 5:37:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0294	0.0200	0.00400	*	mg/L	7/16/2016 7:19:00 AM	KG

Lab ID: 1607371-025 **Client Sample ID** JE-17-DF-#1 **Collection Date:** 7/7/2016 5:37:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00798	0.0200	0.00200		mg/L	7/16/2016 7:19:00 AM	KG

Lab ID: 1607371-026 **Client Sample ID** JE-18-F-#1 **Collection Date:** 7/7/2016 5:42:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0252	0.0200	0.00400	*	mg/L	7/16/2016 7:19:00 AM	KG

Lab ID: 1607371-027 **Client Sample ID** JE-18-DF-#1 **Collection Date:** 7/7/2016 5:42:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00429	0.0200	0.00200		mg/L	7/16/2016 7:19:00 AM	KG

Lab ID: 1607371-028 **Client Sample ID** JE-19-F-#1 **Collection Date:** 7/7/2016 5:44:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00929	0.0200	0.00200		mg/L	7/16/2016 7:19:00 AM	KG

Lab ID: 1607371-029 **Client Sample ID** JE-19-DF-#1 **Collection Date:** 7/7/2016 5:44:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0129	0.0200	0.00200		mg/L	7/16/2016 7:19:00 AM	KG

Lab ID: 1607371-030 **Client Sample ID** JE-LIB-F-#1 **Collection Date:** 7/7/2016 5:34:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.223	0.0200	0.0400	*	mg/L	7/16/2016 7:19:00 AM	KG

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit



WO#: 1607371
CLIENT: Corvallis School District
Project: Jefferson Ele.
PWS Number:
Sample Source:

Received Date: 7/8/2016 3:10:00 PM
Sampler Name Timothy Trivett
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID	JE-LIB-DF-#1	Collection Date:					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	3.29	0.0200	0.400	*	mg/L	7/16/2016 7:19:00 AM	KG

Lab ID:	Client Sample ID	JE-GBATH-DF-#1	Collection Date:					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00970	0.0200	0.00200		mg/L	7/16/2016 7:19:00 AM	KG

Lab ID:	Client Sample ID	JE-BBATH-DF-#1	Collection Date:					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/16/2016 7:19:00 AM	KG

Lab ID:	Client Sample ID	JE-11-F-#1	Collection Date:					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.167	0.0200	0.0200	*	mg/L	7/16/2016 7:19:00 AM	KG

Lab ID:	Client Sample ID	JE-11-DF-#1	Collection Date:					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.164	0.0200	0.0200	*	mg/L	7/16/2016 7:19:00 AM	KG

Lab ID:	Client Sample ID	JE-STAFF-F-#1	Collection Date:					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/16/2016 7:19:00 AM	KG

Lab ID:	Client Sample ID	JE-STRG-F-#1	Collection Date:					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0118	0.0200	0.00200		mg/L	7/16/2016 7:19:00 AM	KG

Lab ID:	Client Sample ID	JE-7-F-#1	Collection Date:					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00586	0.0200	0.00200		mg/L	7/16/2016 7:19:00 AM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1607371
CLIENT: Corvallis School District
Project: Jefferson Ele.
PWS Number:
Sample Source:

Received Date: 7/8/2016 3:10:00 PM
Sampler Name Timothy Trivett
Matrix: Drinking Water
Sample Type:

Lab ID: 1607371-039 **Client Sample ID** JE-7-DF-#1 **Collection Date:** 7/7/2016 5:04:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00713	0.0200	0.00200		mg/L	7/16/2016 7:19:00 AM	KG

Lab ID: 1607371-040 **Client Sample ID** JE-8-F-#1 **Collection Date:** 7/7/2016 5:05:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0194	0.0200	0.00200		mg/L	7/16/2016 7:19:00 AM	KG

Lab ID: 1607371-041 **Client Sample ID** JE-8-DF-#1 **Collection Date:** 7/7/2016 5:05:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00270	0.0200	0.00200		mg/L	7/16/2016 7:19:00 AM	KG

Lab ID: 1607371-042 **Client Sample ID** JE-9-F-#1 **Collection Date:** 7/7/2016 5:09:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.128	0.0200	0.0200	*	mg/L	7/16/2016 7:19:00 AM	KG

Lab ID: 1607371-043 **Client Sample ID** JE-9-DF-#1 **Collection Date:** 7/7/2016 5:09:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00425	0.0200	0.00200		mg/L	7/16/2016 7:19:00 AM	KG

Lab ID: 1607371-044 **Client Sample ID** JE-10-F-#1 **Collection Date:** 7/7/2016 5:07:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00673	0.0200	0.00200		mg/L	7/16/2016 7:19:00 AM	KG

Lab ID: 1607371-045 **Client Sample ID** JE-10-DF-#1 **Collection Date:** 7/7/2016 5:07:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00564	0.0200	0.00200		mg/L	7/16/2016 7:19:00 AM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Analytical Report

Date Reported 7/18/2016

WO#: 1607371
CLIENT: Corvallis School District
Project: Jefferson Ele.
PWS Number:
Sample Source:

Received Date: 7/8/2016 3:10:00 PM
Sampler Name: Timothy Trivett
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID			Collection Date:			
1607371-046	JE-12-F-#1			7/7/2016 5:32:00 AM			
Analyses	Method	Result	MCL	RL Qual Units	Date Analyzed	Analys	
Lead	SM 3113 B	0.0112	0.0200	0.00200	mg/L	7/16/2016 7:19:00 AM	KG

Lab ID:	Client Sample ID			Collection Date:			
1607371-047	JE-12-DF-#1			7/7/2016 5:32:00 AM			
Analyses	Method	Result	MCL	RL Qual Units	Date Analyzed	Analys	
Lead	SM 3113 B	0.00516	0.0200	0.00200	mg/L	7/16/2016 7:19:00 AM	KG

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program Analytes Report

WO#: 1607371
 18-Jul-16

Client: Corvallis School District
Project: Jefferson Ele.

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1607371-001A	JE-1-F-#1	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1607371-002A	JE-1-DF-#1			Lead	A
	1607371-003A	JE-2-F-#1			Lead	A
	1607371-004A	JE-2-DF-#1			Lead	A
	1607371-005A	JE-3-F-#1			Lead	A
	1607371-006A	JE-3-DF-#1			Lead	A
	1607371-007A	JE-4-F-#1			Lead	A
	1607371-008A	JE-4-DF-#1			Lead	A
	1607371-009A	JE-6-F-#1			Lead	A
	1607371-010A	JE-6-DF-#1			Lead	A
	1607371-011A	JE-GYM-DF-#1			Lead	A
	1607371-012A	JE-KITIS-F-#1			Lead	A
	1607371-013A	JE-KITN-F-#1			Lead	A
	1607371-014A	JE-KITS-F-#1			Lead	A
	1607371-015A	JE-KITPF-F-#1			Lead	A
	1607371-016A	JE-HLTH-F-#1			Lead	A
	1607371-017A	JE-WKRM-F-#1			Lead	A
	1607371-018A	JE-PG-DF-#1			Lead	A
	1607371-019A	JE-LIBWKRM-#1			Lead	A
	1607371-020A	JE-14-F-#1			Lead	A
	1607371-021A	JE-14-DF-#1			Lead	A
	1607371-022A	JE-16-F-#1			Lead	A
	1607371-023A	JE-16-DF-#1			Lead	A
	1607371-024A	JE-17-F-#1			Lead	A
	1607371-025A	JE-17-DF-#1			Lead	A
	1607371-026A	JE-18-F-#1			Lead	A
	1607371-027A	JE-18-DF-#1			Lead	A
	1607371-028A	JE-19-F-#1			Lead	A
	1607371-029A	JE-19-DF-#1			Lead	A
	1607371-030A	JE-LIB-F-#1			Lead	A
	1607371-031A	JE-LIB-DF-#1			Lead	A

ORELAP A Accredited

ACCRED



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

**Accreditation Program
 Analytes Report**

WO#: 1607371
 18-Jul-16

Client: Corvallis School District
Project: Jefferson Ele.

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1607371-032A	JE-GBATH-DF-#1	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1607371-033A	JE-BBATH-DF-#1			Lead	A
	1607371-034A	JE-11-F-#1			Lead	A
	1607371-035A	JE-11-DF-#1			Lead	A
	1607371-036A	JE-STAFF-F-#1			Lead	A
	1607371-037A	JE-STRG-F-#1			Lead	A
	1607371-038A	JE-7-F-#1			Lead	A
	1607371-039A	JE-7-DF-#1			Lead	A
	1607371-040A	JE-8-F-#1			Lead	A
	1607371-041A	JE-8-DF-#1			Lead	A
	1607371-042A	JE-9-F-#1			Lead	A
	1607371-043A	JE-9-DF-#1			Lead	A
	1607371-044A	JE-10-F-#1			Lead	A
	1607371-045A	JE-10-DF-#1			Lead	A
	1607371-046A	JE-12-F-#1			Lead	A
	1607371-047A	JE-12-DF-#1			Lead	A



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 1607371

Date: 7/18/2016

Definitions:

% REC: Percent Recovery; a measure of accuracy expressed as a percentage of a measured (recovered) concentration compared to the known concentration added to the sample.

% RPD: Relative Percent Difference; a measure of precision expressed as a percentage of the difference between two duplicates relative to the average concentration.

DF: Dilution factor; the dilution factor applied to the prepared sample.

DUP: Duplicate; aliquots of a sample taken from the same container under laboratory conditions and processed and analyzed independently, used to calculate Precision (%RPD).

LCS: Laboratory Control Sample; prepared by adding a known mass of target analytes to a specified amount of de-ionized water and prepared with the batch of samples, used to calculate Accuracy (%REC).

LCSD: The duplicate sample of the LCS, used to calculate both Accuracy (%REC) and Precision (%RPD)

MBLK: Method Blank; a sample of similar matrix that is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedure, and in which no target analytes or interferences are present at concentrations that impact the analytical results for sample analyses.

MS: Matrix Spike; prepared by adding a known mass of target analytes to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available, used to calculate Accuracy (%REC)

MSD: The duplicate sample of the MS, used to calculate both Accuracy (%REC) and Precision (%RPD)

ND: Not Detected. The analyte level is below the lowest point the laboratory can test for.

PL: Permit limit; only applicable to wastewater reports.

PQL: Practical Quantitation Level or Reporting Limit; the limit to which data is compared for reporting.

Qual: Qualifier that applies to the analyte reported

Original

Page 12 of 13

Definition Base

WO#: 1607371
Date: 7/18/2016

Definitions:

Result: Analyte concentration reported

RL: Reporting Limit/Limit of Quantitation; the limit to which data is compared for reporting. Analyte concentrations below the reporting limit are reported as ND or with a “J” qualifier.

Units: The units in which the analyte concentration is reported.

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
R	RPD outside accepted recovery limits
RL	Reporting Detection Limit
U	Samples with CalcVal < MDL
W	Sample container temperature is out of limit as specified at testcode

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: paul.jennison@corvallis.k12.or.us	City, State, Zip: Corvallis, OR 97333
Client Project: Jefferson Ele.	Sampler: Print <i>Timothy C. Trivett</i>
	Sampler: Signature <i>[Signature]</i>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
JE-1-F-#1	DW/Grab	7-7-16	4:53 AM	Lead	P	1			001A
JE-1-DF-#1	DW/Grab		4:53 AM	Lead	P	1			002A
JE-2-F-#1	DW/Grab		4:55 AM	Lead	P	1			003A
JE-2-DF-#1	DW/Grab		4:55 AM	Lead	P	1			004A
JE-3-F-#1	DW/Grab		4:57 AM	Lead	P	1			005A
JE-3-DF-#1	DW/Grab		4:57 AM	Lead	P	1			006A
JE-4-F-#1	DW/Grab		4:59 AM	Lead	P	1			007A
JE-4-DF-#1	DW/Grab		4:59 AM	Lead	P	1			008A
JE-6-F-#1	DW/Grab		5:02 AM	Lead	P	1			009A
JE-6-DF-#1	DW/Grab		5:02 AM	Lead	P	1			010A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge):		Shipped Via:		Refrigerated	
<input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH		ALG Courier		NA	
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
				7/8/16	1030
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
	7/8/16	1510		7/8/16	1510

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



LABORATORY
 with the Best People

NPUC

CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: paul.jennison@corvallis.k12.or.us	City, State, Zip: Corvallis, OR 97333
Client Project: Jefferson Ele.	Sampler: Print Timothy L. Trivett Sampler: Signature

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
JE-GYM-DF-#1	DW/Grab	7-7-16	5:16am	Lead	P	1			011A
JE-KITIS-F-#1	DW/Grab		5:20AM	Lead	P	1			012A
JE-KITN-F-#1	DW/Grab		5:20AM	Lead	P	1			013A
JE-KITS-F-#1	DW/Grab		5:20AM	Lead	P	1			014A
JE-KITPF-F-#1	DW/Grab		5:20 AM	Lead	P	1			015A
JE-HLTH-F-#1	DW/Grab		5:15 AM	Lead	P	1			016A
JE-WKRM-F-#1	DW/Grab		5:13 AM	Lead	P	1			017A
JE-PG-DF-#1	DW/Grab	7-7-16	4:50 AM	Lead	P	1			018A
JE-LIBWKRM-#1	DW/Grab		5:30 AM	Lead	P	1			019A
	DW/Grab			Lead	P	1			

Notes:	Preservation Check <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Lab ID</th> <th>Date/Time</th> <th>Pre-Preserved</th> <th>pH</th> <th>Tech</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	Lab ID	Date/Time	Pre-Preserved	pH	Tech																																													
Lab ID	Date/Time	Pre-Preserved	pH	Tech																																															

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL _____ <input type="checkbox"/> RUSH _____	Shipped Via: ALG Courier	Refrigerated NA			
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
				7/8/16	1030
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
	7/8/16	1510		7/8/16	1510

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



INDEPENDENT
 AND ACCREDITED

NPUC

CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: paul.jennison@corvallis.k12.or.us	City, State, Zip: Corvallis, OR 97333
Client Project: Jefferson Ele.	Sampler: Print Timothy L Trivett
	Sampler: Signature <i>Timothy L Trivett</i>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
JE-14-F-#1	DW/Grab	7-7-16	5:35 AM	Lead	P	1			020A
JE-14-DF-#1	DW/Grab		5:35 AM	Lead	P	1			021A
JE-16-F-#1	DW/Grab		5:40 AM	Lead	P	1			022A
JE-16-DF-#1	DW/Grab		5:40 AM	Lead	P	1			023A
JE-17-F-#1	DW/Grab		5:37 AM	Lead	P	1			024A
JE-17-DF-#1	DW/Grab		5:37 AM	Lead	P	1			025A
JE-18-F-#1	DW/Grab		5:42 AM	Lead	P	1			026A
JE-18-DF-#1	DW/Grab		5:42 AM	Lead	P	1			027A
JE-19-F-#1	DW/Grab		5:44 AM	Lead	P	1			028A
JE-19-DF-#1	DW/Grab		5:44 AM	Lead	P	1			029A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: ALG Courier	Refrigerated NA			
Relinquished by:	Date	Time	Received by:	Date	Time
			<i>[Signature]</i>		
Relinquished by:	Date	Time	Received by:	Date	Time
			<i>[Signature]</i>	7/8/16	1030
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<i>[Signature]</i>	7/8/16	1510	<i>[Signature]</i>	7/8/16	1510

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



NPUC

CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: paul.jennison@corvallis.k12.or.us	City, State, Zip: Corvallis, OR 97333
Client Project: Jefferson Ele.	Sampler: Print <i>Timothy L Trivett</i>
	Sampler: Signature <i>Timothy Trivett</i>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
JE-LIB-F-#1	DW/Grab	7-7-16	5:34 AM	Lead	P	1			030A
JE-LIB-DF-#1	DW/Grab		5:34 AM	Lead	P	1			031A
JE-GBATH-DF-#1	DW/Grab		5:25 AM	Lead	P	1			032A
JE-BBATH-DF-#1	DW/Grab		5:23 AM	Lead	P	1			033A
JE-MOS-F-#1	DW/Grab			Lead	P	1			
JE-MOS-DF-#1	DW/Grab			Lead	P	1			
JE-II-F-#1	DW/Grab		5:27 AM	Lead	P	1			034A
JE-II-DF-#1	DW/Grab		5:27 AM	Lead	P	1			035A
JE-STAFF-F-#1	DW/Grab		5:29 AM	Lead	P	1			036A
JE-STRG-F-#1	DW/Grab		5:17 AM	Lead	P	1			037A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL _____ <input type="checkbox"/> RUSH _____	Shipped Via: <i>ALG Courier</i>	Refrigerated <i>NA</i>
Relinquished by: _____	Date: _____ Time: _____	Received by: _____
Relinquished by: _____	Date: _____ Time: _____	Received by: <i>[Signature]</i>
Relinquished by: <i>[Signature]</i>	Date: <i>7/8/16</i> Time: <i>1510</i>	Date: <i>7/8/16</i> Time: <i>1030</i>
	Date: _____ Time: _____	Received by Laboratory: <i>[Signature]</i>
	Date: <i>7/8/16</i> Time: <i>1510</i>	Date: <i>7/8/16</i> Time: <i>1510</i>

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



2010 Oregon State
 Seal of Approval

NPUC

CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: paul.jennison@corvallis.k12.or.us	City, State, Zip: Corvallis, OR 97333
Client Project: Jefferson Ele.	Sampler: Print <i>Timothy L. Trivett</i>
	Sampler: Signature <i>Timothy L. Trivett</i>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
JE-7-F-#1	DW/Grab	7-7-16	5:04AM	Lead	P	1			038A
JE-7-DF-#1	DW/Grab		5:04AM	Lead	P	1			039A
JE-8-F-#1	DW/Grab		5:05AM	Lead	P	1			040A
JE-8-DF-#1	DW/Grab		5:05AM	Lead	P	1			041A
JE-9-F-#1	DW/Grab		5:09AM	Lead	P	1			042A
JE-9-DF-#1	DW/Grab		5:09AM	Lead	P	1			043A
JE-10-F-#1	DW/Grab		5:07AM	Lead	P	1			044A
JE-10-DF-#1	DW/Grab		5:07AM	Lead	P	1			045A
JE-12-F-#1	DW/Grab		5:32AM	Lead	P	1			046A
JE-12-DF-#1	DW/Grab		5:32AM	Lead	P	1			047A

Notes:

Preservation Check				
Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge):

NORMAL _____ RUSH _____

Shipped Via: *ALG Courier*

Refrigerated: *NA*

Relinquished by:	Date	Time
Relinquished by:	Date	Time
Relinquished by: <i>[Signature]</i>	7/8/16	1510

Received by:	Date	Time
Received by: <i>[Signature]</i>	7/8/16	1030
Received by Laboratory:	Date	Time
	7/8/16	1510

Received by:	Date	Time
Received by: <i>[Signature]</i>	7/8/16	1030
Received by Laboratory:	Date	Time
	7/8/16	1510