



ALG ORELAP ID #OR100012  
361 West 5th Ave  
Eugene, OR 97401  
TEL: (541) 485-8404 FAX: (541) 484-5995  
Website:

August 05, 2016

Paul Jennison  
Corvallis School District  
P O Box 3509J  
Corvallis, OR 97339  
TEL: (541) 757-5853  
FAX

RE: Lincoln Ele.

Order No.: 1607374

Dear Paul Jennison:

Analytical Laboratory Group received 54 sample(s) on 7/8/2016 for the analyses presented in the following report.

The analysis was performed according to our laboratory's NELAP/TNI-approved quality assurance program. Any exceptions to this quality assurance program are noted on the case narrative.

Testing methods used are sufficiently sensitive enough to meet the requirements that support client/permittee NPDES permits that we have on file. The client is responsible for reviewing reports. The permittee is responsible for meeting permit limits.

There were no problems with the analytical events associated with this report unless noted in the Case Narrative. Analytical results designated with a "J" qualifier are estimated and represent a detection above the Method Detection Limit (MDL or LOD) and less than the Reporting Limit (PQL or RL). These analytes are not reviewed nor narrated as to whether they are laboratory artifacts.

Quality control data is within laboratory defined or method specified acceptance limits except if noted on the case narrative.

If you have any questions regarding these tests results, please feel free to call.

Kimberly Reeve Morghan  
Quality Manager  
361 West 5th Ave  
Eugene, OR 97401

CC:  
Kim Patten



ALG ORELAP ID #OR100012  
361 West 5th Ave  
Eugene, OR 97401  
TEL: (541) 485-8404 FAX: (541) 484-5995  
Website:

## Case Narrative

WO#: 1607374  
Date: 8/5/2016

**CLIENT:** Corvallis School District  
**Project:** Lincoln Ele.

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed ALG lab report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program.

All QA/QC requirements were met except as noted below.

Analytical comments are noted with data flags on the reports and/or below.

**WO#:** 1607374  
**CLIENT:** Corvallis School District  
**Project:** Lincoln Ele.  
**PWS Number:**  
**Sample Source:**

**Received Date:** 7/8/2016 3:10:00 PM  
**Sampler Name:** Paul Jennison  
**Matrix:** Drinking Water  
**Sample Type:**

Lab ID:	Client Sample ID	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
1607374-001	LI-123-F-#1	ND	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

Lab ID:	Client Sample ID	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
1607374-002	LI-123-DF-#1	ND	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

Lab ID:	Client Sample ID	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
1607374-003	LI-117-F-#1	0.0102	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

Lab ID:	Client Sample ID	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
1607374-004	LI-117-DF-#1	0.00353	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

Lab ID:	Client Sample ID	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
1607374-005	LI-118-F-#1	0.00302	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

Lab ID:	Client Sample ID	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
1607374-006	LI-118-DF-#1	ND	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

Lab ID:	Client Sample ID	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
1607374-007	LI-122-F-#1	0.0383	0.0200	0.00400	*	mg/L	7/18/2016 4:36:00 PM	KG

Lab ID:	Client Sample ID	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
1607374-008	LI-132-DF-#1	0.00212	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

**Qualifiers:**

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

**WO#:** 1607374  
**CLIENT:** Corvallis School District  
**Project:** Lincoln Ele.  
**PWS Number:**  
**Sample Source:**

**Received Date:** 7/8/2016 3:10:00 PM  
**Sampler Name:** Paul Jennison  
**Matrix:** Drinking Water  
**Sample Type:**

**Lab ID:** 1607374-009      **Client Sample ID** LI-132-F-#1      **Collection Date:** 7/7/2016 5:22:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

**Lab ID:** 1607374-010      **Client Sample ID** LI-LIB-DF-#1      **Collection Date:** 7/7/2016 5:20:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00672	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

**Lab ID:** 1607374-011      **Client Sample ID** LI-151-F-#1      **Collection Date:** 7/7/2016 4:52:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

**Lab ID:** 1607374-012      **Client Sample ID** LI-151-DF-#1      **Collection Date:** 7/7/2016 4:52:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

**Lab ID:** 1607374-013      **Client Sample ID** LI-149-F-#1      **Collection Date:** 7/7/2016 4:54:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

**Lab ID:** 1607374-014      **Client Sample ID** LI-149-DF-#1      **Collection Date:** 7/7/2016 4:54:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00247	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

**Lab ID:** 1607374-015      **Client Sample ID** LI-146-F-#1      **Collection Date:** 7/7/2016 4:58:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00305	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

**Qualifiers:**

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

**WO#:** 1607374  
**CLIENT:** Corvallis School District  
**Project:** Lincoln Ele.  
**PWS Number:**  
**Sample Source:**

**Received Date:** 7/8/2016 3:10:00 PM  
**Sampler Name:** Paul Jennison  
**Matrix:** Drinking Water  
**Sample Type:**

Lab ID:	Client Sample ID	LI-146-DF-#1	Collection Date:	7/7/2016 4:57:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

Lab ID:	Client Sample ID	LI-145-F-#1	Collection Date:	7/7/2016 4:58:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00258	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

Lab ID:	Client Sample ID	LI-145-DF-#1	Collection Date:	7/7/2016 4:59:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

Lab ID:	Client Sample ID	LI-124-F-#1	Collection Date:	7/7/2016 5:26:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

Lab ID:	Client Sample ID	LI-124-DF-#1	Collection Date:	7/7/2016 5:26:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

Lab ID:	Client Sample ID	LI-165-F-#1	Collection Date:	7/7/2016 5:08:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00550	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

Lab ID:	Client Sample ID	LI-157-F-#1	Collection Date:	7/7/2016 5:06:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

Lab ID:	Client Sample ID	LI-157-DF-#1	Collection Date:	7/7/2016 5:06:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

**Qualifiers:**

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

**WO#:** 1607374  
**CLIENT:** Corvallis School District  
**Project:** Lincoln Ele.  
**PWS Number:**  
**Sample Source:**

**Received Date:** 7/8/2016 3:10:00 PM  
**Sampler Name:** Paul Jennison  
**Matrix:** Drinking Water  
**Sample Type:**

**Lab ID:** 1607374-024      **Client Sample ID** LI-154-F-#1      **Collection Date:** 7/7/2016 5:05:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	0.00304	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG
------	-----------	---------	--------	---------	--	------	----------------------	----

**Lab ID:** 1607374-025      **Client Sample ID** LI-154-DF-#1      **Collection Date:** 7/7/2016 5:05:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	0.00633	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG
------	-----------	---------	--------	---------	--	------	----------------------	----

**Lab ID:** 1607374-026      **Client Sample ID** LI-153-F-#1      **Collection Date:** 7/7/2016 5:00:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG
------	-----------	----	--------	---------	--	------	----------------------	----

**Lab ID:** 1607374-027      **Client Sample ID** LI-153-DF-#1      **Collection Date:** 7/7/2016 5:00:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG
------	-----------	----	--------	---------	--	------	----------------------	----

**Lab ID:** 1607374-028      **Client Sample ID** LI-152-DF-#1      **Collection Date:** 7/7/2016 4:55:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG
------	-----------	----	--------	---------	--	------	----------------------	----

**Lab ID:** 1607374-029      **Client Sample ID** LI-152-F-#1      **Collection Date:** 7/7/2016 4:56:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG
------	-----------	----	--------	---------	--	------	----------------------	----

**Lab ID:** 1607374-030      **Client Sample ID** LI-165-DF-#1      **Collection Date:** 7/7/2016 5:08:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
----------	--------	--------	-----	----	------	-------	---------------	--------

Lead	SM 3113 B	0.00346	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG
------	-----------	---------	--------	---------	--	------	----------------------	----

**Qualifiers:**

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

**WO#:** 1607374  
**CLIENT:** Corvallis School District  
**Project:** Lincoln Ele.  
**PWS Number:**  
**Sample Source:**

**Received Date:** 7/8/2016 3:10:00 PM  
**Sampler Name** Paul Jennison  
**Matrix:** Drinking Water  
**Sample Type:**

Lab ID:	Client Sample ID	LI-112-F-#1	Collection Date:	7/7/2016 5:39:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00784	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

Lab ID:	Client Sample ID	LI-KITS-F-#1	Collection Date:	7/7/2016 5:40:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00329	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

Lab ID:	Client Sample ID	LI-KITN-F-#1	Collection Date:	7/7/2016 5:42:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00300	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

Lab ID:	Client Sample ID	LI-KITE-F-#1	Collection Date:	7/7/2016 5:42:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00308	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

Lab ID:	Client Sample ID	LI-113-DF-#1	Collection Date:	7/7/2016 5:36:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

Lab ID:	Client Sample ID	LI-112-DF-#1	Collection Date:	7/7/2016 5:39:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00294	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

Lab ID:	Client Sample ID	LI-SHRTHALL-DF-#1	Collection Date:	7/7/2016 5:18:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

Lab ID:	Client Sample ID	LI-WHALL-DF-#1	Collection Date:	7/7/2016 5:50:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

**Qualifiers:**

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

**WO#:** 1607374  
**CLIENT:** Corvallis School District  
**Project:** Lincoln Ele.  
**PWS Number:**  
**Sample Source:**

**Received Date:** 7/8/2016 3:10:00 PM  
**Sampler Name:** Paul Jennison  
**Matrix:** Drinking Water  
**Sample Type:**

**Lab ID:** 1607374-039      **Client Sample ID** LI-Entry-DF-#1      **Collection Date:** 7/7/2016 5:28:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00227	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

**Lab ID:** 1607374-040      **Client Sample ID** LI-OLDCLIW-F-#1      **Collection Date:** 7/7/2016 5:46:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/18/2016 4:36:00 PM	KG

**Lab ID:** 1607374-041      **Client Sample ID** LI-LIB-F-#1      **Collection Date:** 7/7/2016 5:20:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

**Lab ID:** 1607374-042      **Client Sample ID** LI-161-F-#1      **Collection Date:** 7/7/2016 5:04:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00220	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

**Lab ID:** 1607374-043      **Client Sample ID** LI-161-DF-#1      **Collection Date:** 7/7/2016 5:04:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00407	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

**Lab ID:** 1607374-044      **Client Sample ID** LI-162-F-#1      **Collection Date:** 7/7/2016 5:10:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00807	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

**Lab ID:** 1607374-045      **Client Sample ID** LI-162-DF-#1      **Collection Date:** 7/7/2016 5:10:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00300	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

**Qualifiers:**

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



**WO#:** 1607374  
**CLIENT:** Corvallis School District  
**Project:** Lincoln Ele.  
**PWS Number:**  
**Sample Source:**

**Received Date:** 7/8/2016 3:10:00 PM  
**Sampler Name:** Paul Jennison  
**Matrix:** Drinking Water  
**Sample Type:**

Lab ID:	Client Sample ID	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
1607374-046	LI-166-F-#1	0.00757	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Lab ID:	Client Sample ID	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
1607374-047	LI-166-DF-#1	0.00345	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Lab ID:	Client Sample ID	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
1607374-048	LI-167-DF-#1	0.00376	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Lab ID:	Client Sample ID	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
1607374-049	LI-167-F-#1	0.00608	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Lab ID:	Client Sample ID	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
1607374-050	LI-113-F-#1	ND	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Lab ID:	Client Sample ID	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
1607374-051	LI-OLDCLIE-F-#1	0.0319	0.0200	0.00800	*	mg/L	7/19/2016 7:44:00 AM	KG

Lab ID:	Client Sample ID	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
1607374-052	LI-128-F-#1	ND	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Lab ID:	Client Sample ID	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
1607374-053	LI-131-F-#1	0.00287	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

**Qualifiers:**

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



ALG ORELAP ID #OR100012  
 361 West 5th Ave  
 Eugene, OR 97401  
 TEL: (541) 485-8404 FAX: (541) 484-5995  
 Website:

# Analytical Report

Date Reported **8/5/2016**

**WO#:** 1607374  
**CLIENT:** Corvallis School District  
**Project:** Lincoln Ele.  
**PWS Number:**  
**Sample Source:**

**Received Date:** 7/8/2016 3:10:00 PM  
**Sampler Name:** Paul Jennison  
**Matrix:** Drinking Water  
**Sample Type:**

Lab ID:	Client Sample ID	LI-1675-F-#1	Collection Date:	7/7/2016 5:13:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0104	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

**Qualifiers:**

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



ALG ORELAP ID #OR100012  
 361 West 5th Ave  
 Eugene, OR 97401  
 TEL: (541) 485-8404 FAX: (541) 484-5995  
 Website:

## Accreditation Program Analytes Report

WO#: 1607374  
 05-Aug-16

**Client:** Corvallis School District  
**Project:** Lincoln Ele.

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1607374-001A	LI-123-F-#1	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1607374-002A	LI-123-DF-#1			Lead	A
	1607374-003A	LI-117-F-#1			Lead	A
	1607374-004A	LI-117-DF-#1			Lead	A
	1607374-005A	LI-118-F-#1			Lead	A
	1607374-006A	LI-118-DF-#1			Lead	A
	1607374-007A	LI-122-F-#1			Lead	A
	1607374-008A	LI-132-DF-#1			Lead	A
	1607374-009A	LI-132-F-#1			Lead	A
	1607374-010A	LI-LIB-DF-#1			Lead	A
	1607374-011A	LI-151-F-#1			Lead	A
	1607374-012A	LI-151-DF-#1			Lead	A
	1607374-013A	LI-149-F-#1			Lead	A
	1607374-014A	LI-149-DF-#1			Lead	A
	1607374-015A	LI-146-F-#1			Lead	A
	1607374-016A	LI-146-DF-#1			Lead	A
	1607374-017A	LI-145-F-#1			Lead	A
	1607374-018A	LI-145-DF-#1			Lead	A
	1607374-019A	LI-124-F-#1			Lead	A
	1607374-020A	LI-124-DF-#1			Lead	A
	1607374-021A	LI-165-F-#1			Lead	A
	1607374-022A	LI-157-F-#1			Lead	A
	1607374-023A	LI-157-DF-#1			Lead	A
	1607374-024A	LI-154-F-#1			Lead	A
	1607374-025A	LI-154-DF-#1			Lead	A
	1607374-026A	LI-153-F-#1			Lead	A
	1607374-027A	LI-153-DF-#1			Lead	A
	1607374-028A	LI-152-DF-#1			Lead	A
	1607374-029A	LI-152-F-#1			Lead	A
	1607374-030A	LI-165-DF-#1			Lead	A
	1607374-031A	LI-112-F-#1			Lead	A

ACCRED ORELAP A Accredited



Delivering more than  
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

## Accreditation Program Analytes Report

WO#: 1607374

05-Aug-16

**Client:** Corvallis School District

**Project:** Lincoln Ele.

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1607374-032A	LI-KITS-F-#1	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1607374-033A	LI-KITN-F-#1			Lead	A
	1607374-034A	LI-KITE-F-#1			Lead	A
	1607374-035A	LI-113-DF-#1			Lead	A
	1607374-036A	LI-112-DF-#1			Lead	A
	1607374-037A	LI-SHRTHALL- DF-#1			Lead	A
	1607374-038A	LI-WHALL-DF-#1			Lead	A
	1607374-039A	LI-Entry-DF-#1			Lead	A
	1607374-040A	LI-OLDCLIW-F-#1			Lead	A
	1607374-041A	LI-LIB-F-#1			Lead	A
	1607374-042A	LI-161-F-#1			Lead	A
	1607374-043A	LI-161-DF-#1			Lead	A
	1607374-044A	LI-162-F-#1			Lead	A
	1607374-045A	LI-162-DF-#1			Lead	A
	1607374-046A	LI-166-F-#1			Lead	A
	1607374-047A	LI-166-DF-#1			Lead	A
	1607374-048A	LI-167-DF-#1			Lead	A
	1607374-049A	LI-167-F-#1			Lead	A
	1607374-050A	LI-113-F-#1			Lead	A
	1607374-051A	LI-OLDCLIE-F-#1			Lead	A
	1607374-052A	LI-128-F-#1			Lead	A
	1607374-053A	LI-131-F-#1			Lead	A
	1607374-054A	LI-1675-F-#1			Lead	A

ORELAP A Accredited

ACCRED

Original #1607374# v1

Page 12 of 14



Delivering more than  
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

## Definition Base

WO#: 1607374

Date: 8/5/2016

---

### Definitions:

**% REC:** Percent Recovery; a measure of accuracy expressed as a percentage of a measured (recovered) concentration compared to the known concentration added to the sample.

**% RPD:** Relative Percent Difference; a measure of precision expressed as a percentage of the difference between two duplicates relative to the average concentration.

**DF:** Dilution factor; the dilution factor applied to the prepared sample.

**DUP:** Duplicate; aliquots of a sample taken from the same container under laboratory conditions and processed and analyzed independently, used to calculate Precision (%RPD).

**LCS:** Laboratory Control Sample; prepared by adding a known mass of target analytes to a specified amount of de-ionized water and prepared with the batch of samples, used to calculate Accuracy (%REC).

**LCSD:** The duplicate sample of the LCS, used to calculate both Accuracy (%REC) and Precision (%RPD)

**MBLK:** Method Blank; a sample of similar matrix that is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedure, and in which no target analytes or interferences are present at concentrations that impact the analytical results for sample analyses.

**MS:** Matrix Spike; prepared by adding a known mass of target analytes to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available, used to calculate Accuracy (%REC)

**MSD:** The duplicate sample of the MS, used to calculate both Accuracy (%REC) and Precision (%RPD)

**ND:** Not Detected. The analyte level is below the lowest point the laboratory can test for.

**PL:** Permit limit; only applicable to wastewater reports.

**PQL:** Practical Quantitation Level or Reporting Limit; the limit to which data is compared for reporting.

**Qual:** Qualifier that applies to the analyte reported

---

Original

Page 13 of 14



Delivering more than  
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

## Definition Base

WO#: 1607374

Date: 8/5/2016

---

### Definitions:

Result: Analyte concentration reported

RL: Reporting Limit/Limit of Quantitation; the limit to which data is compared for reporting. Analyte concentrations below the reporting limit are reported as ND or with a “J” qualifier.

Units: The units in which the analyte concentration is reported.

### Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
R	RPD outside accepted recovery limits
RL	Reporting Detection Limit
U	Samples with CalcVal < MDL
W	Sample container temperature is out of limit as specified at testcode

# Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE  
 EUGENE, OREGON 97401  
 800-262-5973/541-485-8404 Fax 541-484-5995  
 Email: [alglabs@alglabsinc.com](mailto:alglabs@alglabsinc.com)



Member of the  
 Oregon Analytical Laboratory Association

NPUC

## CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: <a href="mailto:paul.jennison@corvallis.k12.or.us">paul.jennison@corvallis.k12.or.us</a>	City, State, Zip: Corvallis, OR 97333
Client Project: Lincoln Ele.	Sampler: Print PAUL JENNISON
	Sampler: Signature 

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
LI-123-F-#1	DW/Grab	7-7-16	05:29	Lead	P	1			001A
LI-123-DF-#1	DW/Grab		05:29	Lead	P	1			002A
LI-117-F-#1	DW/Grab		05:34	Lead	P	1			003A
LI-117-DF-#1	DW/Grab		05:34	Lead	P	1			004A
LI-118-F-#1	DW/Grab		05:33	Lead	P	1			005A
LI-118-DF-#1	DW/Grab		05:33	Lead	P	1			006A
LI-122-F-#1	DW/Grab		05:31	Lead	P	1			007A
LI-132-DF-#1	DW/Grab		05:22	Lead	P	1			008A
LI-132-F-#1	DW/Grab		05:22	Lead	P	1			009A
LI-118-DF-#1	DW/Grab		05:20	Lead	P	1			010A

Notes:	<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th colspan="5">Preservation Check</th> </tr> <tr> <th>Lab ID</th> <th>Date/Time</th> <th>Pre-Preserved</th> <th>pH</th> <th>Tech</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	Preservation Check					Lab ID	Date/Time	Pre-Preserved	pH	Tech																																													
Preservation Check																																																								
Lab ID	Date/Time	Pre-Preserved	pH	Tech																																																				

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL _____ <input type="checkbox"/> RUSH _____	Shipped Via: ALG Courier	Refrigerated NA
---	-----------------------------	--------------------

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
	7/8/16	1510		7/8/16	1030
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
	7/8/16	1510		7/8/16	1510

# Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE  
 EUGENE, OREGON 97401  
 800-262-5973/541-485-8404 Fax 541-484-5995  
 Email: [alglabs@alglabsinc.com](mailto:alglabs@alglabsinc.com)



NPUC

## CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: paul.jennison@corvallis.k12.or.us	City, State, Zip: Corvallis, OR 97333
Client Project: Lincoln Ele.	Sampler: Print PAUL Jennison Sampler: Signature 

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
LI-151-F-#1	DW/Grab	7-7-16	04:52	Lead	P	1			011A
LI-151-DF-#1	DW/Grab		04:52	Lead	P	1			012A
LI-149-F-#1	DW/Grab		04:54	Lead	P	1			013A
LI-149-DF-#1	DW/Grab		04:54	Lead	P	1			014A
LI-146-F-#1	DW/Grab		04:58	Lead	P	1			015A
LI-146-DF-#1	DW/Grab		04:57	Lead	P	1			016A
LI-145-F-#1	DW/Grab		04:58	Lead	P	1			017A
LI-145-DF-#1	DW/Grab		04:59	Lead	P	1			018A
LI-124-F-#1	DW/Grab		05:26	Lead	P	1			019A
LI-124-DF-#1	DW/Grab		05:26	Lead	P	1			020A

Notes:	<b>Preservation Check</b>				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: ALG Courier	Refrigerated NA
---	-----------------------------	--------------------

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
	7/8/16	1510		7/8/16	1030
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
	7/8/16	1510		7/8/16	1510



# Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE  
 EUGENE, OREGON 97401  
 800-262-5973/541-485-8404 Fax 541-484-5995  
 Email: [alglabs@alglabsinc.com](mailto:alglabs@alglabsinc.com)



NPUC

## CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: paul.jennison@corvallis.k12.or.us	City, State, Zip: Corvallis, OR 97333
Client Project: Lincoln Ele.	Sampler: Print PAUL JENNISON
	Sampler: Signature 

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
L1-165-F-#1	DW/Grab	7-7-16	05:08	Lead	P	1			021A
L1-157-F-#1	DW/Grab		05:06	Lead	P	1			022A
L1-157-DF-#1	DW/Grab		05:06	Lead	P	1			023A
L1-154-F-#1	DW/Grab		05:05	Lead	P	1			024A
L1-154-DF-#1	DW/Grab		05:05	Lead	P	1			025A
L1-153-F-#1	DW/Grab		05:00	Lead	P	1			026A
L1-153-DF-#1	DW/Grab		05:00	Lead	P	1			027A
L1-152-DF-#1	DW/Grab		04:55	Lead	P	1			028A
L1-152-F-#1	DW/Grab		04:56	Lead	P	1			029A
L1-165-DF-#1	DW/Grab		05:08	Lead	P	1			030A

Notes:	<b>Preservation Check</b>																																																		
	<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Lab ID</th> <th>Date/Time</th> <th>Pre-Preserved</th> <th>pH</th> <th>Tech</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	Lab ID	Date/Time	Pre-Preserved	pH	Tech																																													
Lab ID	Date/Time	Pre-Preserved	pH	Tech																																															

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL _____ <input type="checkbox"/> RUSH _____	Shipped Via: <u>ALG Courier</u>	Refrigerated: <u>NA</u>
Relinquished by: _____ Date: _____ Time: _____	Received by:  Date: _____ Time: _____	Date: _____ Time: _____
Relinquished by: _____ Date: _____ Time: _____	Received by:  Date: <u>7/8/16</u> Time: <u>1030</u>	Date: _____ Time: _____
Relinquished by:  Date: <u>7/8/16</u> Time: <u>1510</u>	Received by Laboratory:  Date: <u>7/8/16</u> Time: <u>1510</u>	Date: _____ Time: _____

# Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE  
 EUGENE, OREGON 97401  
 800-262-5973/541-485-8404 Fax 541-484-5995  
 Email: [alglabs@alglabsinc.com](mailto:alglabs@alglabsinc.com)



NPUC

## CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: <a href="mailto:paul.jennison@corvallis.k12.or.us">paul.jennison@corvallis.k12.or.us</a>	City, State, Zip: Corvallis, OR 97333
Client Project: Lincoln Ele.	Sampler: Print PAUL JENNISON Sampler: Signature 

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
LI-112-F-#1	DW/Grab	7-7-16	05:39	Lead	P	1			031A 0539
LI-KITS-F-#1	DW/Grab		05:40	Lead	P	1			032A
LI-KITN-F-#1	DW/Grab		05:42	Lead	P	1			033A
LI-KITE-F-#1	DW/Grab		05:42	Lead	P	1			034A
LI-113-DF-#1	DW/Grab		05:36	Lead	P	1			035A
LI-112-DF-#1	DW/Grab		05:39	Lead	P	1			036A
LI-SHRTHALL-DF-#1	DW/Grab		05:18	Lead	P	1			037A
LI-WHALL-DF-#1	DW/Grab		05:50	Lead	P	1			038A
LI-ENTRY-DF-#1	DW/Grab		05:28	Lead	P	1			039A
LI-OLDCLIW-F-#1	DW/Grab		05:46	Lead	P	1			040A

Notes:	<b>Preservation Check</b>				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: ALG Courier	Refrigerated NA
---	-----------------------------	--------------------

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
				7/8/16	1030
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
	7/8/16	1510		7/8/16	1510

# Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE  
 EUGENE, OREGON 97401  
 800-262-5973/541-485-8404 Fax 541-484-5995  
 Email: [alglabs@alglabsinc.com](mailto:alglabs@alglabsinc.com)



Empowering Your  
 Performance

NPUC

## CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: paul.jennison@corvallis.k12.or.us	City, State, Zip: Corvallis, OR 97333
Client Project: Lincoln Ele.	Sampler: Print PAUL JENNISON Sampler: Signature 

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only			
		Date	Time		Type	#	Pres	T °C
L1-L1B-F-#1	DW/Grab	7-7-16	05:20	Lead	P	1		0448A
L1-161-F-#1	DW/Grab		05:04	Lead	P	1		042A
L1-161-DF-#1	DW/Grab		05:04	Lead	P	1		043A
L1-162-F-#1	DW/Grab		05:10	Lead	P	1		044A
L1-162-DF-#1	DW/Grab		05:10	Lead	P	1		045A
L1-166-F-#1	DW/Grab		05:12	Lead	P	1		046A
L1-166-DF-#1	DW/Grab		05:12	Lead	P	1		047A
L1-167-DF-#1	DW/Grab		05:13	Lead	P	1		048A
L1-167-F-#1	DW/Grab		05:13	Lead	P	1		049A
L1-113-F-#1	DW/Grab		05:36	Lead	P	1		050A

Notes:	<b>Preservation Check</b>				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: ALG Courier	Refrigerated NA
Relinquished by: _____ Date: _____ Time: _____	Received by: _____ Date: _____ Time: _____	Date: _____ Time: _____
Relinquished by: _____ Date: _____ Time: _____	Received by: Date: 7/8/16 Time: 1030	Date: _____ Time: _____
Relinquished by: Date: 7/8/16 Time: 1510	Received by Laboratory: Date: 7/8/16 Time: 1510	Date: _____ Time: _____

# Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE  
 EUGENE, OREGON 97401  
 800-262-5973/541-485-8404 Fax 541-484-5995  
 Email: [alglabs@alglabsinc.com](mailto:alglabs@alglabsinc.com)



NPUC

## CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: <a href="mailto:paul.jennison@corvallis.k12.or.us">paul.jennison@corvallis.k12.or.us</a>	City, State, Zip: Corvallis, OR 97333
Client Project: Lincoln Ele.	Sampler: Print PAUL JENNISON Sampler: Signature 

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
LI-OLDCLIE-F-#1	DW/Grab	7-7-16	05:46	Lead	P	1			051A
LI-128-F-#1	DW/Grab		05:24	Lead	P	1			052A
LI-131-F-#1	DW/Grab		05:24	Lead	P	1			053A
LI-167S-F-#1	DW/Grab		05:13	Lead	P	1			054A
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			

Notes:	<b>Preservation Check</b>				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: ALG Courier	Refrigerated NA			
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
	7/8/16	1510		7/8/16	1030
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
	7/8/16	1510		7/8/16	1510