



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

August 05, 2016

Paul Jennison
Corvallis School District
P O Box 3509J
Corvallis, OR 97339
TEL: (541) 757-5853
FAX

RE: Wilson Ele.

Order No.: 1607381

Dear Paul Jennison:

Analytical Laboratory Group received 51 sample(s) on 7/8/2016 for the analyses presented in the following report.

The analysis was performed according to our laboratory's NELAP/TNI-approved quality assurance program. Any exceptions to this quality assurance program are noted on the case narrative.

Testing methods used are sufficiently sensitive enough to meet the requirements that support client/permittee NPDES permits that we have on file. The client is responsible for reviewing reports. The permittee is responsible for meeting permit limits.

There were no problems with the analytical events associated with this report unless noted in the Case Narrative. Analytical results designated with a "J" qualifier are estimated and represent a detection above the Method Detection Limit (MDL or LOD) and less than the Reporting Limit (PQL or RL). These analytes are not reviewed nor narrated as to whether they are laboratory artifacts.

Quality control data is within laboratory defined or method specified acceptance limits except if noted on the case narrative.

If you have any questions regarding these tests results, please feel free to call.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401

CC:
Kim Patten



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Case Narrative

WO#: 1607381
Date: 8/5/2016

CLIENT: Corvallis School District
Project: Wilson Ele.

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed ALG lab report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program.

All QA/QC requirements were met except as noted below.

Analytical comments are noted with data flags on the reports and/or below.

WO#: 1607381
CLIENT: Corvallis School District
Project: Wilson Ele.
PWS Number:
Sample Source:

Received Date: 7/8/2016 3:10:00 PM
Sampler Name Timothy Trivett
Matrix: Drinking Water
Sample Type:

Lab ID: 1607381-001 **Client Sample ID** WI-1-F-1 **Collection Date:** 7/6/2016 4:55:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00222	0.0200	0.00200		mg/L	7/20/2016 3:39:00 PM	PG

Lab ID: 1607381-002 **Client Sample ID** WI-1-DF-1 **Collection Date:** 7/6/2016 4:55:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/20/2016 3:39:00 PM	PG

Lab ID: 1607381-003 **Client Sample ID** WI-2-F-1 **Collection Date:** 7/6/2016 4:58:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00771	0.0200	0.00200		mg/L	7/20/2016 3:39:00 PM	PG

Lab ID: 1607381-004 **Client Sample ID** WI-2-DF-1 **Collection Date:** 7/6/2016 4:58:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00527	0.0200	0.00200		mg/L	7/20/2016 3:39:00 PM	PG

Lab ID: 1607381-005 **Client Sample ID** WI-3-F-1 **Collection Date:** 7/6/2016 5:00:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0106	0.0200	0.00200		mg/L	7/20/2016 3:39:00 PM	PG

Lab ID: 1607381-006 **Client Sample ID** WI-3-DF-1 **Collection Date:** 7/6/2016 5:00:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/20/2016 3:39:00 PM	PG

Lab ID: 1607381-007 **Client Sample ID** WI-4-F-1 **Collection Date:** 7/6/2016 5:02:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0104	0.0200	0.00200		mg/L	7/20/2016 3:39:00 PM	PG

Lab ID: 1607381-008 **Client Sample ID** WI-4-DF-1 **Collection Date:** 7/6/2016 5:02:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/20/2016 3:39:00 PM	PG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



WO#: 1607381
CLIENT: Corvallis School District
Project: Wilson Ele.
PWS Number:
Sample Source:

Received Date: 7/8/2016 3:10:00 PM
Sampler Name: Timothy Trivett
Matrix: Drinking Water
Sample Type:

Lab ID: 1607381-009 **Client Sample ID:** WI-5-F-1 **Collection Date:** 7/6/2016 5:04:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0137	0.0200	0.00200		mg/L	7/20/2016 3:39:00 PM	PG

Lab ID: 1607381-010 **Client Sample ID:** WI-5-DF-1 **Collection Date:** 7/6/2016 5:04:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/20/2016 3:39:00 PM	PG

Lab ID: 1607381-011 **Client Sample ID:** WI-6-F-1 **Collection Date:** 7/6/2016 5:06:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0154	0.0200	0.00200		mg/L	7/20/2016 3:39:00 PM	PG

Lab ID: 1607381-012 **Client Sample ID:** WI-6-DF-1 **Collection Date:** 7/6/2016 5:06:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/20/2016 3:39:00 PM	PG

Lab ID: 1607381-013 **Client Sample ID:** WI-7-F-1 **Collection Date:** 7/6/2016 5:08:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00627	0.0200	0.00200		mg/L	7/20/2016 3:39:00 PM	PG

Lab ID: 1607381-014 **Client Sample ID:** WI-7-DF-1 **Collection Date:** 7/6/2016 5:08:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00215	0.0200	0.00200		mg/L	7/20/2016 3:39:00 PM	PG

Lab ID: 1607381-015 **Client Sample ID:** WI-8-DF-1 **Collection Date:** 7/6/2016 5:10:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/20/2016 3:39:00 PM	PG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



WO#: 1607381
CLIENT: Corvallis School District
Project: Wilson Ele.
PWS Number:
Sample Source:

Received Date: 7/8/2016 3:10:00 PM
Sampler Name: Timothy Trivett
Matrix: Drinking Water
Sample Type:

Lab ID: 1607381-016 **Client Sample ID:** WI-9-F-1 **Collection Date:** 7/6/2016 5:12:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0342	0.0200	0.00400	*	mg/L	7/20/2016 3:39:00 PM	PG

Lab ID: 1607381-017 **Client Sample ID:** WI-9-DF-1 **Collection Date:** 7/6/2016 5:12:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00486	0.0200	0.00200		mg/L	7/20/2016 9:18:00 PM	KG

Lab ID: 1607381-018 **Client Sample ID:** WI-10-F-1 **Collection Date:** 7/6/2016 5:14:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0105	0.0200	0.00200		mg/L	7/20/2016 9:18:00 PM	KG

Lab ID: 1607381-019 **Client Sample ID:** WI-10-DF-1 **Collection Date:** 7/6/2016 5:14:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0107	0.0200	0.00200		mg/L	7/20/2016 9:18:00 PM	KG

Lab ID: 1607381-020 **Client Sample ID:** WI-11-F-1 **Collection Date:** 7/6/2016 5:24:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0355	0.0200	0.00400	*	mg/L	7/20/2016 9:18:00 PM	KG

Lab ID: 1607381-021 **Client Sample ID:** WI-11-DF-1 **Collection Date:** 7/6/2016 5:24:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0287	0.0200	0.00400	*	mg/L	7/20/2016 9:18:00 PM	KG

Lab ID: 1607381-022 **Client Sample ID:** WI-12-F-1 **Collection Date:** 7/6/2016 5:25:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.240	0.0200	0.0400	*	mg/L	7/22/2016 10:42:00 AM	KG

Lab ID: 1607381-023 **Client Sample ID:** WI-12-DF-1 **Collection Date:** 7/6/2016 5:25:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0607	0.0200	0.00800	*	mg/L	7/20/2016 9:18:00 PM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1607381
CLIENT: Corvallis School District
Project: Wilson Ele.
PWS Number:
Sample Source:

Received Date: 7/8/2016 3:10:00 PM
Sampler Name: Timothy Trivett
Matrix: Drinking Water
Sample Type:

Lab ID: 1607381-024 **Client Sample ID:** WI-13-F-1 **Collection Date:** 7/6/2016 5:27:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0279	0.0200	0.00400	*	mg/L	7/14/2016 2:40:00 PM	KG

Lab ID: 1607381-025 **Client Sample ID:** WI-13-DF-1 **Collection Date:** 7/6/2016 5:27:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0200	0.0200	0.00400	*	mg/L	7/14/2016 2:40:00 PM	KG

Lab ID: 1607381-026 **Client Sample ID:** WI-14-F-1 **Collection Date:** 7/6/2016 5:29:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0141	0.0200	0.00200		mg/L	7/20/2016 9:18:00 PM	KG

Lab ID: 1607381-027 **Client Sample ID:** WI-14-DF-1 **Collection Date:** 7/6/2016 5:29:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0154	0.0200	0.00200		mg/L	7/20/2016 9:18:00 PM	KG

Lab ID: 1607381-028 **Client Sample ID:** WI-15-F-1 **Collection Date:** 7/6/2016 5:31:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0120	0.0200	0.00200		mg/L	7/20/2016 9:18:00 PM	KG

Lab ID: 1607381-029 **Client Sample ID:** WI-15-DF-1 **Collection Date:** 7/6/2016 5:31:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0172	0.0200	0.00200		mg/L	7/14/2016 2:40:00 PM	KG

Lab ID: 1607381-030 **Client Sample ID:** WI-16-F-1 **Collection Date:** 7/6/2016 5:39:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	1.03	0.0200	0.160	*	mg/L	7/22/2016 10:42:00 AM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1607381
CLIENT: Corvallis School District
Project: Wilson Ele.
PWS Number:
Sample Source:

Received Date: 7/8/2016 3:10:00 PM
Sampler Name: Timothy Trivett
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID	WI-16-DF-1	Collection Date:	7/6/2016 5:39:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.347	0.0200	0.0400	*	mg/L	7/22/2016 10:42:00 AM	KG

Lab ID:	Client Sample ID	WI-17-F-1	Collection Date:	7/6/2016 5:33:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0320	0.0200	0.00400	*	mg/L	7/20/2016 9:18:00 PM	KG

Lab ID:	Client Sample ID	WI-17-DF-1	Collection Date:	7/6/2016 5:33:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0270	0.0200	0.00400	*	mg/L	7/20/2016 9:18:00 PM	KG

Lab ID:	Client Sample ID	WI-18-F-1	Collection Date:	7/6/2016 5:40:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.905	0.0200	0.160	*	mg/L	7/22/2016 10:42:00 AM	KG

Lab ID:	Client Sample ID	WI-18-DF-1	Collection Date:	7/6/2016 5:40:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.419	0.0200	0.0800	*	mg/L	7/22/2016 10:42:00 AM	KG

Lab ID:	Client Sample ID	WI-19-F-1	Collection Date:	7/6/2016 5:35:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0253	0.0200	0.00400	*	mg/L	7/20/2016 9:18:00 PM	KG

Lab ID:	Client Sample ID	WI-19-DF-1	Collection Date:	7/6/2016 5:35:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0131	0.0200	0.00200		mg/L	7/20/2016 9:18:00 PM	KG

Lab ID:	Client Sample ID	WI-20-F-1	Collection Date:	7/6/2016 5:42:00 AM				
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.729	0.0200	0.0800	*	mg/L	7/22/2016 10:42:00 AM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 1607381
CLIENT: Corvallis School District
Project: Wilson Ele.
PWS Number:
Sample Source:

Received Date: 7/8/2016 3:10:00 PM
Sampler Name: Timothy Trivett
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID	WI-20-DF-1	Collection Date:					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.475	0.0200	0.0800	*	mg/L	7/22/2016 10:42:00 AM	KG

Lab ID:	Client Sample ID	WI-21-F-1	Collection Date:					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.261	0.0200	0.0400	*	mg/L	7/22/2016 10:42:00 AM	KG

Lab ID:	Client Sample ID	WI-21-DF-1	Collection Date:					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.205	0.0200	0.0400	*	mg/L	7/22/2016 10:42:00 AM	KG

Lab ID:	Client Sample ID	WI-LIB-F-1	Collection Date:					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0293	0.0200	0.00400	*	mg/L	7/20/2016 9:18:00 PM	KG

Lab ID:	Client Sample ID	WI-26-F-1	Collection Date:					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0289	0.0200	0.00400	*	mg/L	7/20/2016 9:18:00 PM	KG

Lab ID:	Client Sample ID	WI-CNS-F-1	Collection Date:					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0383	0.0200	0.00400	*	mg/L	7/20/2016 9:18:00 PM	KG

Lab ID:	Client Sample ID	WI-HLTH-F-1	Collection Date:					
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.191	0.0200	0.0200	*	mg/L	7/20/2016 9:18:00 PM	KG

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit



WO#: 1607381
CLIENT: Corvallis School District
Project: Wilson Ele.
PWS Number:
Sample Source:

Received Date: 7/8/2016 3:10:00 PM
Sampler Name: Timothy Trivett
Matrix: Drinking Water
Sample Type:

Lab ID: 1607381-046 **Client Sample ID** WI-GBATH-DF-1 **Collection Date:** 7/6/2016 5:18:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00334	0.0200	0.00200		mg/L	7/20/2016 9:18:00 PM	KG

Lab ID: 1607381-047 **Client Sample ID** WI-BBATH-DF-1 **Collection Date:** 7/6/2016 5:18:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/20/2016 9:18:00 PM	KG

Lab ID: 1607381-048 **Client Sample ID** WI-KITIS-F-1 **Collection Date:** 7/6/2016 5:22:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00797	0.0200	0.00200		mg/L	7/20/2016 9:18:00 PM	KG

Lab ID: 1607381-049 **Client Sample ID** WI-KITS-F-1 **Collection Date:** 7/6/2016 5:22:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/20/2016 9:18:00 PM	KG

Lab ID: 1607381-050 **Client Sample ID** WI-KITN-F-1 **Collection Date:** 7/6/2016 5:22:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00528	0.0200	0.00200		mg/L	7/20/2016 9:18:00 PM	KG

Lab ID: 1607381-051 **Client Sample ID** WI-GYM-DF-1 **Collection Date:** 7/6/2016 5:20:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/20/2016 9:18:00 PM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program Analytes Report

WO#: 1607381
 05-Aug-16

Client: Corvallis School District
Project: Wilson Ele.

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1607381-001A	WI-1-F-1	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1607381-002A	WI-1-DF-1			Lead	A
	1607381-003A	WI-2-F-1			Lead	A
	1607381-004A	WI-2-DF-1			Lead	A
	1607381-005A	WI-3-F-1			Lead	A
	1607381-006A	WI-3-DF-1			Lead	A
	1607381-007A	WI-4-F-1			Lead	A
	1607381-008A	WI-4-DF-1			Lead	A
	1607381-009A	WI-5-F-1			Lead	A
	1607381-010A	WI-5-DF-1			Lead	A
	1607381-011A	WI-6-F-1			Lead	A
	1607381-012A	WI-6-DF-1			Lead	A
	1607381-013A	WI-7-F-1			Lead	A
	1607381-014A	WI-7-DF-1			Lead	A
	1607381-015A	WI-8-DF-1			Lead	A
	1607381-016A	WI-9-F-1			Lead	A
	1607381-017A	WI-9-DF-1			Lead	A
	1607381-018A	WI-10-F-1			Lead	A
	1607381-019A	WI-10-DF-1			Lead	A
	1607381-020A	WI-11-F-1			Lead	A
	1607381-021A	WI-11-DF-1			Lead	A
	1607381-022A	WI-12-F-1			Lead	A
	1607381-023A	WI-12-DF-1			Lead	A
	1607381-024A	WI-13-F-1			Lead	A
	1607381-025A	WI-13-DF-1			Lead	A
	1607381-026A	WI-14-F-1			Lead	A
	1607381-027A	WI-14-DF-1			Lead	A
	1607381-028A	WI-15-F-1			Lead	A
	1607381-029A	WI-15-DF-1			Lead	A
	1607381-030A	WI-16-F-1			Lead	A
	1607381-031A	WI-16-DF-1			Lead	A

ORELAP A Accredited

ACCRED



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program Analytes Report

WO#: 1607381
 05-Aug-16

Client: Corvallis School District
Project: Wilson Ele.

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1607381-032A	WI-17-F-1	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	1607381-033A	WI-17-DF-1			Lead	A
	1607381-034A	WI-18-F-1			Lead	A
	1607381-035A	WI-18-DF-1			Lead	A
	1607381-036A	WI-19-F-1			Lead	A
	1607381-037A	WI-19-DF-1			Lead	A
	1607381-038A	WI-20-F-1			Lead	A
	1607381-039A	WI-20-DF-1			Lead	A
	1607381-040A	WI-21-F-1			Lead	A
	1607381-041A	WI-21-DF-1			Lead	A
	1607381-042A	WI-LIB-F-1			Lead	A
	1607381-043A	WI-26-F-1			Lead	A
	1607381-044A	WI-CNS-F-1			Lead	A
	1607381-045A	WI-HLTH-F-1			Lead	A
	1607381-046A	WI-GBATH-DF-1			Lead	A
	1607381-047A	WI-BBATH-DF-1			Lead	A
	1607381-048A	WI-KITIS-F-1			Lead	A
	1607381-049A	WI-KITS-F-1			Lead	A
	1607381-050A	WI-KITN-F-1			Lead	A
	1607381-051A	WI-GYM-DF-1			Lead	A



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 1607381

Date: 8/5/2016

Definitions:

% REC: Percent Recovery; a measure of accuracy expressed as a percentage of a measured (recovered) concentration compared to the known concentration added to the sample.

% RPD: Relative Percent Difference; a measure of precision expressed as a percentage of the difference between two duplicates relative to the average concentration.

DF: Dilution factor; the dilution factor applied to the prepared sample.

DUP: Duplicate; aliquots of a sample taken from the same container under laboratory conditions and processed and analyzed independently, used to calculate Precision (%RPD).

LCS: Laboratory Control Sample; prepared by adding a known mass of target analytes to a specified amount of de-ionized water and prepared with the batch of samples, used to calculate Accuracy (%REC).

LCSD: The duplicate sample of the LCS, used to calculate both Accuracy (%REC) and Precision (%RPD)

MBLK: Method Blank; a sample of similar matrix that is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedure, and in which no target analytes or interferences are present at concentrations that impact the analytical results for sample analyses.

MS: Matrix Spike; prepared by adding a known mass of target analytes to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available, used to calculate Accuracy (%REC)

MSD: The duplicate sample of the MS, used to calculate both Accuracy (%REC) and Precision (%RPD)

ND: Not Detected. The analyte level is below the lowest point the laboratory can test for.

PL: Permit limit; only applicable to wastewater reports.

PQL: Practical Quantitation Level or Reporting Limit; the limit to which data is compared for reporting.

Qual: Qualifier that applies to the analyte reported

Original

Page 12 of 13

Definitions:

Result: Analyte concentration reported

RL: Reporting Limit/Limit of Quantitation; the limit to which data is compared for reporting. Analyte concentrations below the reporting limit are reported as ND or with a “J” qualifier.

Units: The units in which the analyte concentration is reported.

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
R	RPD outside accepted recovery limits
RL	Reporting Detection Limit
U	Samples with CalcVal < MDL
W	Sample container temperature is out of limit as specified at testcode

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: paul.jennison@corvallis.k12.or.us	City, State, Zip: Corvallis, OR 97333
Client Project: Wilson EIE.	Sampler: Print Tim TRIVETT Sampler: Signature

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
W1-1-F-#1	DW/Grab	7-6-16	4:55 AM	Lead	P	1			001A
W1-1-DF-#1	DW/Grab		4:55 AM	Lead	P	1			002A
W1-2-F-#1	DW/Grab		4:58 AM	Lead	P	1			003A
W1-2-DF-#1	DW/Grab		4:58 AM	Lead	P	1			004A
W1-3-F-#1	DW/Grab		5:00 AM	Lead	P	1			005A
W1-3-DF-#1	DW/Grab		5:00 AM	Lead	P	1			006A
W1-4-F-#1	DW/Grab		5:02 AM	Lead	P	1			007A
W1-4-DF-#1	DW/Grab		5:02 AM	Lead	P	1			008A
W1-5-F-#1	DW/Grab		5:04 AM	Lead	P	1			009A
W1-5-DF-#1	DW/Grab		5:04 AM	Lead	P	1			010A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input type="checkbox"/> NORMAL _____ <input type="checkbox"/> RUSH _____	Shipped Via: ALG Carrier	Refrigerated no			
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	7/8/16	1030
Relinquished by:	7/8/16	1510	Received by Laboratory:	7/8/16	1510

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



PROVIDING THE HIGHEST QUALITY
 AND SERVICE

CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: paul.jennison@corvallis.k12.or.us	City, State, Zip: Corvallis, OR 97333
Client Project: Wilson Ele.	Sampler: Print Tim Trivett
	Sampler: Signature <i>[Signature]</i>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
W1-6-F-#1	DW/Grab	7-6-16	5:06 AM	Lead	P	1			011A
W1-6-DF-#1	DW/Grab		5:06 AM	Lead	P	1			012A
W1-7-F-#1	DW/Grab		5:08 AM	Lead	P	1			013A
W1-7-DF-#1	DW/Grab		5:08 AM	Lead	P	1			014A
W1-8-F-#1	DW/Grab		NT	Lead	P	1			015A
W1-8-DF-#1	DW/Grab		5:10 AM	Lead	P	1			015A 016A
W1-9-F-#1	DW/Grab		5:12 AM	Lead	P	1			016A 017A
W1-9-DF-#1	DW/Grab		5:12 AM	Lead	P	1			017A 018A
W1-10-F-#1	DW/Grab		5:14 AM	Lead	P	1			018A 019A
W1-10-DF-#1	DW/Grab		5:14 AM	Lead	P	1			019A 020A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: ALG Courier	Refrigerated No
--	-----------------------------	--------------------

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
			<i>[Signature]</i>	7/8/16	1030
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
MF	7/8/16	1510	<i>[Signature]</i>	7/8/16	1510

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: paul.jennison@corvallis.k12.or.us	City, State, Zip: Corvallis, OR 97333
Client Project: Wilson Ele.	Sampler: Print Tim Trivett
	Sampler: Signature <i>[Signature]</i>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only					
		Date	Time		Type	#	Pres	T °C	Lab ID	
W1-11-F-#1	DW/Grab	7-6-16	5:24AM	Lead	P	1			021A	020A
W1-11-DF-#1	DW/Grab		5:24AM	Lead	P	1			022A	021A
W1-12-F-#1	DW/Grab		5:25AM	Lead	P	1			023A	022A
W1-12-DF-#1	DW/Grab		5:25AM	Lead	P	1			024A	023A
W1-13-F-#1	DW/Grab		5:27AM	Lead	P	1			025A	024A
W1-13-DF-#1	DW/Grab		5:27AM	Lead	P	1			026A	025A
W1-14-F-#1	DW/Grab		5:29AM	Lead	P	1			027A	026A
W1-14-DF-#1	DW/Grab		5:29AM	Lead	P	1			028A	027A
W1-15-F-#1	DW/Grab		5:31	Lead	P	1			029A	028A
W1-15-DF-#1	DW/Grab		5:31	Lead	P	1			030A	029A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input type="checkbox"/> NORMAL _____ <input type="checkbox"/> RUSH _____	Shipped Via: ALG Courier	Refrigerated no			
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<i>[Signature]</i>	7/8/16	1510	<i>[Signature]</i>	7/8/16	1510

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Phosphorus, Nitrate, and Ammonia

CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: paul.jennison@corvallis.k12.or.us	City, State, Zip: Corvallis, OR 97333
Client Project: Wilson Ele.	Sampler: Print Tim TRIVETT
	Sampler: Signature <i>[Signature]</i>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only					
		Date	Time		Type	#	Pres	T °C	Lab ID	
W1-16-F-#1	DW/Grab	7-6-16	5:39 AM	Lead	P	1			031A	030A
W1-16-DF-#1	DW/Grab		5:39 AM	Lead	P	1			032A	031A
W1-17-F-#1	DW/Grab		5:33 AM	Lead	P	1			033A	032A
W1-17-DF-#1	DW/Grab		5:33 AM	Lead	P	1			034A	033A
W1-18-F-#1	DW/Grab		5:40 AM	Lead	P	1			035A	034A
W1-18-DF-#1	DW/Grab		5:40 AM	Lead	P	1			036A	035A
W1-19-F-#1	DW/Grab		5:35 AM	Lead	P	1			037A	036A
W1-19-DF-#1	DW/Grab		5:35 AM	Lead	P	1			038A	037A
W1-20-F-#1	DW/Grab		5:42 AM	Lead	P	1			039A	039A
W1-20-DF-#1	DW/Grab		5:42 AM	Lead	P	1			040A	039A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: ALG Courier	Refrigerated: NO
---	------------------------------------	----------------------------

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
<i>[Signature]</i>	7/8/16	1510	MF	7/8/16	1030
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<i>[Signature]</i>	7/8/16	1510	<i>[Signature]</i>	7/8/16	1510

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Environmental Testing
 Industrial Hygiene

CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: paul.jennison@corvallis.k12.or.us	City, State, Zip: Corvallis, OR 97333
Client Project: Wilson Ele.	Sampler: Print <u>Tim Trivett</u> Sampler: Signature <u>[Signature]</u>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only						
		Date	Time		Type	#	Pres	T °C	Lab ID		
WI-21-F-#1	DW/Grab	7-6-16	5:43 ^{AM}	Lead	P	1			041A	041A	
WI-21-DF-#1	DW/Grab		5:43 ^{AM}	Lead	P	1			042	041A	
WI-LIB-F-#1	DW/Grab		5:37 ^{AM}	Lead	P	1			042A	042A	
WI-26-F-#1	DW/Grab		5:37 ^{AM}	Lead	P	1			043A	043A	
WI-CNS-F-#1	DW/Grab		5:16 ^{AM}	Lead	P	1			044A	044A	
WI-HLTH-F-#1	DW/Grab		5:16 ^{AM}	Lead	P	1			045A	045A	
WI-GBATH-DF-#1	DW/Grab		5:18 ^{AM}	Lead	P	1			046A	046A	
WI-BBATH-DF-#1	DW/Grab		5:18 ^{AM}	Lead	P	1			047A	047A	
WI-KITPF-F-#1	DW/Grab		NT	Lead	P	1					
WI-KITIS-F-#1	DW/Grab		5:22 ^{AM}	Lead	P	1			048A	048A	048A

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: <u>ARC Courier</u>	Refrigerated: <u>NO</u>
--	---------------------------------	-------------------------

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
			<u>M F</u>	7/8/16	1030
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<u>M F</u>	7/8/16	1310	<u>[Signature]</u>	7/8/16	1510

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Environmental Health
 and Safety Dept.

CHAIN OF CUSTODY

Attention: Paul Jennison	Client: Corvallis School District
Phone: 541-757-5877	Address: PO Box 3509J
Email: paul.jennison@corvallis.k12.or.us	City, State, Zip: Corvallis, OR 97333
Client Project: Wilson Ele.	Sampler: Print Tim Trivett
	Sampler: Signature <i>[Signature]</i>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
WI-KITS-F-#1	DW/Grab	7-6-16	5:22 AM	Lead	P	1			049A
WI-KITN-F-#1	DW/Grab		5:22 AM	Lead	P	1			050A
WI-WCP-DF-#1	DW/Grab	 	5:22 AM	NT - Lead	P	1			
WI-GYM-DF-#1	DW/Grab		5:20 AM	Lead	P	1			051A
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			

Notes:	Preservation Check				
	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input type="checkbox"/> NORMAL _____ <input type="checkbox"/> RUSH _____	Shipped Via: ALG Courier	Refrigerated NO			
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
			MF	7/8/16	1030
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
MF	7/8/16	1310	<i>[Signature]</i>	7/8/16	1570